

Monthly Generation Performance Report

October 2024



Introduction

As part of the Transmission and Distribution System Operation and Maintenance Agreement (OMA), LUMA serves as both the operator of the electric grid and as the island's System Operator.

As the Operator of the electric grid, LUMA oversees and maintains the transmission and distribution system that is critical to delivering energy to over 1.5 million Puerto Rican customers.

As the System Operator, LUMA monitors the performance of GeneraPR and other private generators' generation units, implements dispatch of available units, and plans and maintains adequate generation reserve levels to meet customer's energy demands.

While LUMA does not generate energy, LUMA's responsibility as the System Operator includes measuring the performance of the island's generation fleet. This report summarizes generation performance, identifies trends, compares facility performance, and provides a high-level picture of the entire generation portfolio.



Table of Contents

Executive Summary

Operations

- System Level Performance
 - System Reserve Status
 - System Heat Rate
 - o System Availability
- Plant/Unit Level Performance
 - Available Capacity
 - o Heat Rate
 - Generation and Capacity Factor
 - Planned Outage Hours
 - Maintenance Outage Hours
 - Forced Outage Hours
 - o Renewables Capacity Factor

Economics

- Fuel Prices
- Fuel Production Costs

About This Report

- Glossary of Terms
- Plant and Unit List



Executive Summary – October Performance

Overview

The maximum peak demand for October 2024 was approximately 3,130 MW.

San Juan 6 (220 MW) is currently offline and is expected to return to service on February 28, 2025. San Juan 7 (100 MW), AES 1 (254 MW), Aguirre 2 (450 MW) are out of operation and their return date is yet to be determined; Palo Seco 4 (216 MW) is expected to return to service by June 5, 2025

Major Events

In October, the electric system experienced 15 generation events that led to load shedding, with 9 caused by underfrequency due to generation unit trips and 6 caused by generation shortfall.

For October, the hourly reserve levels averaged 743 MW, with 359 hours during the month having less than 750 MW in reserves (equal to 48% of the time.)

The forecast for November 2024 shows fewer reserve levels to the same month last year (November 2023), with 476 MW average reserves forecasted versus 685 MW seen for the same month last year.

The System Availability for the month of October was 50%.


- Genera 45%
- AES 72%
- EcoEléctrica 99%



System Reserves

System Reserves is the amount of generating capacity available to meet peak or abnormally high demands for power and to generate power during scheduled or unscheduled outages.

Target: A Reserves >750MW per the System Operation Principles




*Refer to Glossary of Terms on page 22 for a list of definitions and formulas.

System Availability

The System Availability is the maximum expected output that generating units can supply to system load, adjusted for scheduled or unscheduled outages. In this graph, the availability is being compared with the total generation required to meet demand to visualize the gap between the two lines (the gap represents the reserves level).

Target: A bigger gap between availability and generation demand means a better chance of recovery in emergency events due to adequate reserves.




*Refer to Glossary of Terms on page 22 for a list of definitions and formulas.

LUMAPR.COM

Load Shed Events

Load shed events can occur due to unexpected generation unit losses (Unit Performance Load Shed Events). Also, when the demand for electricity exceeds available supply levels, LUMA, as the system operator and in compliance with its responsibilities under the T&D OMA, implements load shedding to stabilize the electric system and prevent larger and longer outages (Generation Shortfall Events).

LUMA does not generate energy and can only operate the system with the electricity that is provided by GeneraPR, PREPA, and other island generators.



*Refer to Glossary of Terms on page 22 for a list of definitions and formulas.

System Heat Rate

The System Heat Rate measures the efficiency of the system to convert fuel into electricity. System Heat Rate will vary depending on the available generation units and required resources to satisfy electrical demand. It is calculated as energy consumed (MMBtu) / energy produced (MWh). The forecasted Heat Rate is determined by the last forecast calculated for the Fuel Clause Adjustment Factor.

Target: **V** Lower heat rates represent higher efficiency.



Forecasted vs Actual Heat Rate

Available Capacity – Baseload Units

Available Capacity is the maximum output that a unit can generate at any given time. The Availability Rate indicates the percent of available capacity out of the total nameplate capacity. Variables in the chart below are shown in MW (gross) representing an average over the month.

Target: A higher availability indicates the plant is able to produce power closer to its nameplate capacity.

0		•			· ·	· · ·	-							
	Available Capacity (MW) and Availability Rate (AR)	Nov-23	Dec-23	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-2
AES	510	MM	249	263	370	330	463	406	249	257	440	466	371	364
Nameplate Cap: 508	N D J F M A M J J A S O	AR	49%	52%	73%	65%	91%	80%	49%	51%	87%	92%	73%	729
EcoElectrica	550	MM	531	550	550	547	550	550	543	566	566	252	391	56 ⁻
Nameplate Cap: 566	N D J F M A M J J A S O	AR	97%	100%	100%	99%	100%	100%	99%	103%	103%	45%	69%	999
Genera Aguirre	900	MM	257	152	210	368	341	303	505	592	440	314	147	169
Nameplate Cap: 900	NDJFMAMJJASO	AR	29%	17%	23%	41%	38%	34%	56%	66%	49%	35%	16%	199
Genera Costa	410	MM	363	366	48	3	105	316	403	533	599	546	643	56
Nameplate Cap: 820	N D J F M A M J J A S O	AR	44%	45%	6%	0%	13%	39%	49%	65%	73%	67%	78%	68
Genera Palo Seco	602	MM	121	0	0	0	0	0	0	0	27	173	198	19
Nameplate Cap: 602	NDJFMAMJJASO	AR	20%	0%	0%	0%	0%	0%	0%	0%	4%	29%	33%	32
Genera San Juan		MM	510	652	723	478	585	250	266	337	392	398	375	25
Nameplate Cap: 840	N D J F M A M J J A S O	AR	61%	78%	86%	57%	70%	30%	32%	40%	47%	47%	45%	31
Total Baseload	4200	MM	2384	2329	2249	2070	2043	1826	1967	2285	2462	2149	2125	21(
Nameplate Cap: 4220	0 N D J F M A M J J A S O	AR	52%	51%	49%	45%	48%	43%	47%	54%	58%	51%	50%	50

*Refer to Glossary of Terms on page 22 for a list of definitions and formulas.

Available Capacity – Peaker Units

Available Capacity is the maximum output that a unit can generate at any given time. The Availability Rate indicates the percent of available capacity out of the total nameplate capacity. Variables in the chart below are shown in MW representing an average over the month.

Target: A higher availability indicates the plant is able to produce power closer to its nameplate capacity.

	Avail	able Capacity	(MW) a	nd Avail	ability Ra	ate (AR)		Nov-23	Dec-23	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24
Genera Aguirre Combined Cvcle	592 296 0						ΜW	191	185	150	138	127	170	178	201	197	206	216	257
Nameplate Cap: 592	Ŭ		MA	M J	JAS	\$ O	AR	32%	31%	25%	23%	21%	29%	30%	34%	33%	35%	37%	43%
Genera Cambalache	248 124 0	~					MM	76	104	152	156	153	155	155	151	151	152	155	152
Nameplate Cap: 248	Ŭ	NDJF	MA	MJ	JAS	6 O	AR	31%	42%	62%	63%	62%	63%	63%	61%	61%	61%	63%	61%
Genera Mayaguez	220 110 0						MM	19	26	24	33	50	37	42	53	52	46	54	51
Nameplate Cap: 220	U	NDJF	MA	MJ	JAS	s o	AR	9%	12%	11%	15%	23%	17%	19%	24%	23%	21%	25%	23%
Genera Palo Seco (Inc.	208 104		-				MΜ	186	182	183	182	176	151	165	153	140	141	140	135
Mobile-Pack) Nameplate Cap: 207	0		M A		J A S	s o	AR	90%	88%	89%	88%	85%	73%	80%	74%	68%	68%	68%	65%
Palo Seco TM	150 75 0		~			_	MM	151	150	147	143	96	62	80	86	84	87	79	82
Nameplate Cap: 90			MA	MJ	JAS	s o	AR	100%	100%	98%	95%	107%	69%	89%	96%	93%	97%	88%	91%
San Juan TM	250 125 0		~				MM	202	196	201	200	205	245	236	226	224	218	239	212
Nameplate Cap: 250	Ŭ	NDJF	MA	MJ	JAS	s o	AR	101%	98%	101%	100%	82%	98%	95%	91%	89%	87%	96%	85%
Other Peakers	264 132						MM	62	61	71	68	71	71	60	54	52	51	54	61
Nameplate Cap: 264	0		MA	MJ	JAS	s o	AR	24%	23%	27%	26%	27%	27%	23%	21%	20%	19%	20%	23%
Total Peakers	1871 936		$ \geq$				MM	535	557	581	577	879	891	917	924	899	900	937	950
Nameplate Cap: 1871	0	NDJF	MA	MJ	JAS	s o	AR	35%	36%	38%	38%	47%	48%	49%	49%	48%	48%	50%	51%



*Refer to Glossary of Terms on page 22 for a list of definitions and formulas.

Heat Rate – Baseload Units

Heat Rate measures the efficiency of a power plant to convert fuel into electricity. It is calculated as energy consumed (MMBtu) / energy produced (MWh).

Target: **V** Lower heat rates represent higher efficiency.

		Heat Rate (MMBtu/MWh)	Nov-23	Dec-23	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24
AES	6,000	N D J F M A M J J A S O	9,800	9,800	9,800	9,800	10,620	10,620	10,620	10,620	10,620	10,620	10,620	10,620
EcoElectrica	0	N D J F M A M J J A S O	7,945	7,945	7,957	7,957	7,957	7,957	7,881	7,881	7,881	7,881	7,881	7,881
Genera Aguirre	6,000 0	N D J F M A M J J A S O	11,008	11,034	11,207	11,397	11,268	11,117	10,934	10,951	11,220	11,225	11,142	11,177
Genera Costa Sur	6,000	N D J F M A M J J A S O	10,857	10,838	11,323	40,045	11,913	10,397	10,703	10,562	10,343	10,854	10,738	10,976
Genera Palo Seco	12,000 6,000 0	N D J F M A M J J A S O	10,254	-	-	-	-	-	-	-	10,264	9,696	9,648	9,296
Genera San Juan	12,000 6,000 0	N D J F M A M J J A S O	9,317	8,956	8,973	9,432	8,714	8,882	8,796	10,188	10,817	11,016	9,485	9,263
Total Baseload	12,000 6,000 0		9,477	9,267	8,968	9,381	9,510	9,564	9,687	9,904	10,007	10,275	9,817	9,761

*Refer to Glossary of Terms on page 22 for a list of definitions and formulas.

Heat Rate – Peaker Units

Heat Rate measures the efficiency of a power plant to convert fuel into electricity. It is calculated as energy consumed (MMBtu) / energy produced (MWh).

Target: **V** Lower heat rates represent higher efficiency.

		Heat Rate (MMBtu/MWh)	Nov-23	Dec-23	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24
Genera Aguirre Combined Cycle	18,000 12,000 6,000 0	N D J F M A M J J A S O	14,969	14,921	14,671	14,989	13,867	11,936	11,751	12,482	13,852	11,888	12,289	11,844
Genera Cambalache	18,000 12,000 6,000 0	N D J F M A M J J A S O	12,435	13,231	12,834	12,785	12,872	12,640	12,407	12,756	12,876	12,361	12,343	12,361
Genera Mayaguez	18,000 12,000 6,000 0	N D J F M A M J J A S O	10,801	11,013	10,882	10,945	11,029	11,107	10,882	11,040	10,832	10,908	10,868	10,861
Genera Palo Seco (Inc. Mobile Pack)	18,000 12,000 6,000 0	N D J F M A M J J A S O	15,981	14,925	15,146	16,487	15,205	14,397	13,787	13,445	13,662	12,270	12,669	12,033
Palo Seco TM & San Juan TM	18,000 12,000 6,000 0	N D J F M A M J J A S O	-	-	-	-	-	11,706	11,137	11,032	10,961	10,983	10,993	11,534
Other Peakers	18,000 12,000 6,000 0	N D J F M A M J J A S O	14,893	14,771	15,064	15,462	14,062	12,730	15,043	14,990	6,912	14,031	14,563	13,000
Total Peakers	18,000 12,000 6,000 0	N D J F M A M J J A S O	13,962	13,195	12,755	12,951	12,710	5,416	6,168	5,087	4,468	6,354	6,246	6,525

*Refer to Glossary of Terms on page 22 for a list of definitions and formulas.

Generation and Capacity Factor – Baseload Units

Generation indicates the average amount of energy each plant produced per month, in MW (gross). The Capacity Factor measures what percentage of the nameplate capacity was used to produce energy during that time period.

Target: A Higher Capacity Factor, and a Generation closer to the nameplate capacity will represent a better utilization of the units.

		Average (Generatio	on (MV	V) an	d Cap	acity Facto	r	Nov-23	Dec-23	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24
AES	508 254		<u>~</u>			~		MW	248	253	355	320	452	412	249	251	437	449	357	365
Nameplate Cap: 508	0	N D J	FΜ	AN	1 J	JΑ	s o	CF	49%	50%	70%	63%	89%	81%	49%	49%	86%	88%	70%	72%
EcoElectrica	550 275							MM	403	410	412	405	398	412	399	415	412	235	292	404
Nameplate Cap: 566	0	NDJ	FΜ					CF	73%	75%	75%	74%	72%	75%	73%	75%	75%	42%	52%	71%
Genera Aguirre	900 - 450 -				_			MW	190	156	134	284	243	221	418	466	346	237	125	148
Nameplate Cap: 900	0 г		FΜ	A M	J	JA	s o	CF	21%	17%	15%	32%	27%	25%	46%	52%	38%	26%	14%	16%
Genera Costa Sur				_	_		~	MM	304	291	37	1	101	270	358	486	482	435	543	495
Nameplate Cap: 820	0	ИДЛ	FΜ	AN	L J	JΑ	S O	CF	37%	35%	5%	0%	12%	33%	44%	59%	59%	53%	66%	60%
Genera Palo Seco	602 301							MW	105	0	0	0	0	0	0	0	28	139	150	150
Nameplate Cap: 602	U	N D J					a s o	CF	18%	0%	0%	0%	0%	0%	0%	0%	5%	23%	25%	25%
Genera San Juan	840 420 0							MW	417	397	473	380	380	227	254	306	343	302	330	229
Nameplate Cap: 840		N D J	FΜ	AN	IJ	JA	a s o	CF	50%	47%	56%	45%	45%	27%	30%	36%	41%	36%	39%	27%
Total Baseload	4200 2100							MW	2024	1858	1763	1735	1573	1542	1679	1924	2047	1798	1797	1790
Nameplate Cap: 4370	0		F M	AN	I N	JA	A S O	CF	44%	41%	39%	38%	37%	37%	40%	46%	49%	43%	43%	42%

*Refer to Glossary of Terms on page 22 for a list of definitions and formulas.

Generation and Capacity Factor – Peaker Units

Generation indicates the average amount of energy each plant produced per month (MW). The Capacity Factor measures what percentage of the nameplate capacity was used to produce energy during that time period.

Target: A Higher Capacity Factor, and a Generation closer to the nameplate capacity will represent a better utilization of the units.

0 1 2			0.0016	alony n		00111 0.				0				
	Average Generation (MW) and Capacity Factor	N	ov-23	Dec-23	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-2
Genera Aguirre Combined Cycle	592	MM	75	47	49	42	31	79	101	75	48	114	120	149
Nameplate Cap: 592		ხ 1	13%	8%	8%	7%	5%	13%	17%	13%	8%	19%	20%	259
Genera Cambalache	248 —	MΜ	30	18	31	35	24	57	71	37	27	67	74	68
Nameplate Cap: 247.5	NDJFMAMJJASO	ხ 1	12%	7%	13%	14%	10%	23%	29%	15%	11%	27%	30%	279
Genera Mayaguez		MM	23	50	77	72	56	79	90	66	49	69	68	66
Nameplate Cap: 220	NDJFMAMJJASO	ხ 1	10%	23%	35%	33%	25%	36%	41%	30%	22%	31%	31%	309
Genera Palo Seco (Inc. Mobile- Pack) Nameplate Cap: 207	0	CF MW	9 5%	10	9 4%	13 6%	15 7%	14 7%	32 15%	21 10%	10	37 18%	37 18%	40
Palo Seco TM	150	>	154	154	151	143	96	66	82	85	60	80	77	80
Nameplate Cap: 150	N D J F M A M J J A S O	ხ 1	03%	103%	101%	95%	106%	74%	91%	94%	66%	89%	85%	89
San Juan TM		MW 2	202	196	201	201	189	241	222	203	179	180	217	19
Nameplate Cap: 200		ხ 1	01%	98%	101%	101%	76%	96%	89%	81%	71%	72%	87%	779
Other Peakers (Genera)	264	MΜ	23	7	12	9	7	16	22	6	7	14	13	12
Nameplate Cap: 264	NDJFMAMJJASO	ц C	9%	3%	5%	3%	3%	6%	8%	2%	3%	5%	5%	5%
Total Peakers	765	MW	161	131	178	171	418	552	620	494	379	561	605	60
Nameplate Cap: 1530.5	N D J F M A M J J A S O	ხ 1	11%	9%	12%	11%	22%	30%	33%	26%	20%	30%	32%	33




*Refer to Glossary of Terms on page 22 for a list of definitions and formulas.

Planned Outage Hours – Baseload Units

Planned Outage Hours represents the shutdown of a generating unit or facility for inspection or maintenance, in accordance with an advance schedule; represented in hours. This scoreboard compares the scheduled outage hours with the actual duration of the outage.

Target: **V** A smaller gap between actuals and planned hours represents a more accurate planification.



*Refer to Glossary of Terms on page 22 for a list of definitions and formulas.

Maintenance Outage Hours – Baseload Units

Maintenance Outage Hours represent the shutdown of a generating unit or facility for nonemergency reasons or conditions which need repair outside of the advance schedule; represented in hours per unit.

Target: **v** Less maintenance hours represents more available capacity in the system to meet demand.

	Maintenance Outage Hours	Nov-23				Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24
AES	400 200 0 N D J F M A M J J A S O	288	264	0	0	0	0	24	120	11	0	0	0
EcoElectrica	1 1 0 NDJFMAMJJASO	0	0	0	0	0	0	0	0	0	0	0	0
Genera Aguirre	1 1 0 NDJFMAMJJASO	0	0	0	0	0	0	0	0	0	0	0	0
Genera Costa Sur	400 200 0 N D J F M A M J J A S O	283	139	84	53	24	56	43	0	9	0	0	0
Genera Palo Seco	1 1 0 N D J F M A M J J A S O	0	0	0	0	0	0	0	0	0	0	0	0
Genera San Juan	1000 500 0 N D J F M A M J J A S O	136	551	34	48	105	0	30	0	19	0	72	114
Total Baseload	1000 500 0 N D J F M A M J J A S O	707	954	118	101	129	56	98	120	38	0	72	114

*Refer to Glossary of Terms on page 22 for a list of definitions and formulas.

Forced Outage Hours and Rate – Baseload Units

Forced Outage Hours represent the shutdown of a generating unit or facility for emergency reasons or a condition in which the generating equipment is unavailable for load due to an unanticipated breakdown; represented in hours per unit. The Forced Outage Rate represents the percentage of time the unit was in a Forced Outage condition out of the total time the unit was expected to be available.

Target: **v** Less forced outage hours and a smaller outage rate represents more available capacity in the system to meet demand.

	Forced Outage Hours and Outage Rate		Nov-23	Dec-23	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24
AES	100%	Hrs	24	218	265	432	0	92	166	47	88	0	279	327
	0% N D J F M A M J J A S O	%	3%	19%	18%	31%	0%	6%	16%	5%	6%	0%	19%	22%
EcoElectrica	\wedge	Hrs	35	0	0	7	0	0	48	0	0	964	28	28
	0% N D J F M A M J J A S O	%	2%	0%	0%	0%	0%	0%	2%	0%	0%	43%	1%	1%
Genera Aguirre		Hrs	862	898	1014	370	686	799	250	81	337	609	1026	1032
	0% N D J F M A M J J A S O	%	60%	60%	68%	27%	46%	55%	17%	6%	23%	41%	71%	69%
Genera Costa Sur	-	Hrs	720	720	1391	1356	1021	720	290	134	172	233	0	102
Sui	0% N D J F M A M J J A S O	%	74%	67%	119%	128%	115%	156%	85%	24%	18%	19%	0%	18%
Genera Palo Seco		Hrs	2278	2854	2854	2662	2806	2782	2638	2782	2751	2445	2159	2278
	0% N D J F M A M J J A S O	%	79%	96%	96%	96%	94%	97%	89%	97%	92%	84%	75%	77%
Genera San Juan		Hrs	2193	1589	1521	2198	1964	3897	3714	3809	3609	3946	2206	3087
	0% N D J F M A M J J A S O	%	39%	31%	26%	41%	35%	68%	63%	66%	62%	66%	39%	54%
Total Baseload	100%	Hrs	6112	6279	7044	7025	6477	8290	7106	6853	6958	8197	5697	6855
	0% N D J F M A M J J A S O	%	23%	23%	25%	27%	41%	55%	45%	45%	45%	52%	38%	44%

*Refer to Glossary of Terms on page 22 for a list of definitions and formulas.

Renewables Capacity Factor - Solar

The Capacity Factor measures the actual production of electricity over the theoretical maximum output (nameplate capacity). For Renewable projects, the Capacity Factor is expected to be lower due to the solar and wind cycles.

Target: A higher Capacity Factor represents a better utilization of the maximum capacity the project is able to produce.

		Ave	rage	Pro	oduc	:tion	(MV	V) a	nd C	apa	acity	Facto	r	Nov-23	Dec-23	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24
AES Ilumina	20 10 0	_											MM	3	3	4	3	4	4	4	4	4	4	4	4
Nameplate Cap: 20	0	Ν	D	J	ΓI	М	A N	l I	J	A	S	0	СЕ	17%	17%	19%	17%	21%	20%	20%	19%	19%	19%	19%	18%
Windmar Cantera Martinó	2.0 1.0 0.0												MW	0.4	0.4	0.4	0.4	0.5	0.5	0.4	0.4	0.3	0.3	0.3	0.2
Nameplate Cap: 2.1	0.0	Ν	D.	J	FΙ	M	A N	1	IJ	А	S	0	CF	19%	21%	21%	18%	25%	22%	20%	19%	14%	14%	13%	11%
San Fermín	20 10 0	_											MM	2	2	2	2	2	2	1	1	1	2	1	1
Nameplate Cap: 20	0	Ν	D	J	FΙ	М	A N	1 1	J	A	S	0	CF	10%	10%	10%	9%	12%	10%	7%	7%	7%	8%	7%	7%
Horizon Energy	10 5												MM	2	2	2	2	3	3	3	3	3	3	3	2
Nameplate Cap: 10	0	Ν	D	J	FI	М	A N	1 1	J	A	S	0	СF	24%	24%	25%	22%	27%	26%	27%	26%	26%	27%	26%	24%
Oriana Energy	40 20												MW	9	9	10	10	10	11	10	11	10	11	10	9
Nameplate Cap: 45	0	N	D	J	FΙ	М	A N	1 1	J	A	S	0	СF	20%	20%	22%	21%	23%	24%	23%	24%	22%	24%	23%	21%
Windmar Coto Laurel	10 5 0												MM	2	2	2	2	2	2	2	1	1	2	1	1
Nameplate Cap: 10	Ŭ	Ν	D	J	FΙ	М	A N	l I	J	A	S	0	СF	17%	17%	16%	16%	19%	19%	18%	15%	14%	16%	10%	14%
Fonroche Humacao	40 20 0	_											MM	6	6	7	7	9	8	8	7	7	9	8	6
Nameplate Cap: 40	0	Ν	D	J	FΙ	М	A N	1 1	J	A	S	0	СЕ	15%	16%	16%	17%	21%	19%	20%	18%	18%	21%	20%	14%
Total Solar	140 70 0												MW	25	25	27	26	31	29	29	27	27	29	27	24
Nameplate Cap: 147	0	Ν	D	J	F	М	A I	A .	1 1	A	S	0	СF	17%	17%	18%	17%	21%	20%	19%	19%	18%	20%	19%	16%

*Refer to Glossary of Terms on page 22 for a list of definitions and formulas.

LUMAPR.COM

Renewables Capacity Factor – Wind and Landfill

The Capacity Factor measures the actual production of electricity over the theoretical maximum output (nameplate capacity). For Renewable projects, the Capacity Factor is expected to be lower due to the solar and wind cycles.


Target: A higher Capacity Factor represents a better utilization of the maximum capacity the project is able to produce.

		Av	erag	je Pr	rodu	ctior	n (M	W) a	and	Сар	acit	y Fac	tor	Nov-	23	Dec-23	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24
Pattern Santa Isabel	74 37 0	_											MM	12		12	17	10	13	12	12	16	22	18	12	6
Nameplate Cap: 95	Ŭ	Ν	D	J	F	Μ	А	М	J	J	A	s o	Ę	179	6	15%	22%	13%	14%	13%	13%	17%	23%	18%	13%	6%
Punta Lima	26 13 0						~						MM	3		4	6	4	5	6	3	5	9	6	3	2
Nameplate Cap: 26	Ŭ	Ν	D	J	F	Μ	A	М	J	l	A	s o	Ę	5 119	6	17%	25%	14%	20%	25%	12%	20%	33%	23%	12%	8%
Landfill Gas Fajardo	2.4 1.2 0.0												MM	0.3	;	0.5	0.2	0.0	0.0	0.1	0.1	0.0	0.1	0.0	0.10	0.8
Nameplate Cap: 2.4	0.0	Ν	D	J	F	Μ	А	М	J	J	A	s o	Ę	5 119	6	22%	10%	0%	0%	5%	5%	0%	4%	2%	4%	33%
Landfill Gas Toa Baja	2.4 1.2 0.0						~		_				MM	1.2	2	1.1	1.0	1.0	1.0	1.1	0.9	0.8	1.2	0.5	0.4	0.02
Nameplate Cap: 2.4		N	D	J	F	Μ	А	М	J	l	A	S O	Ľ	49%	6	46%	42%	43%	41%	47%	36%	33%	48%	21%	15%	1%
Total Wind and Landfill	80 40 0	_											MM	17		17	24	14	20	20	16	22	32	24	16	8
Nameplate Cap: 80	_	Ν	D	J	F	Μ	A	М	J	J	A	S O	Ľ	169	6	17%	23%	14%	16%	16%	13%	18%	25%	19%	13%	7%

*Refer to Glossary of Terms on page 22 for a list of definitions and formulas.


Fuel Prices

Fuel Price shows the prices paid for fuel used by PREPA and private generators, both in terms of MMBtus and Barrel of Oil Equivalent (BOE). The Fuel Price is divided by Fuel Type to better illustrate the contribution to the total Fuel Price for the month.



Variable Production Costs

Variable Production Costs are predominantly fuel costs and reflect the cost to produce one MWh of energy. In the graph, the cost is shown separately for Baseload units and Peaker units. The weighted average cost indicates the cost per MWh of energy produced for the System Portfolio.



Peaker

-----System Total

Variable Production Costs (\$/MWh)

Baseload

Glossary of Terms

Term	Definition	Formula
Heat Rate	Measures the efficiency of a power plant to convert fuel into electricity. It is the amount of energy used by a power plant to generate one kilowatt-hour (kWh) of electricity. The more efficient the generator is, the lower the heat rate.	MMBtu consumption by all units in the station during a specific period / MWh produced by the same units in the same period
Reserves	Amount of generating capacity available to meet peak or abnormally high demands for power and to generate power during scheduled or unscheduled outages.	Available Capacity (MW) during the reported period minus the Actual Generation (MW) during the same period
Available Capacity	The maximum output, commonly expressed in megawatts (MW), that generating equipment can supply to system load, adjusted for scheduled or unscheduled outages.	N/A – value is provided for each unit
Availability Rate	The ratio of the maximum output that can be supplied to system load for the period of time considered to the nameplate capacity.	Average available capacity for a specific period (MW) / nameplate capacity
Production	The amount of electric energy produced.	N/A – value is provided for each unit
Capacity Factor	The ratio of the electrical energy produced by a generating unit for the period of time considered to the nameplate capacity.	The average energy produced by all units in the plant during a specific period (MWh) / Nameplate capacity for the plant
Planned Outage Hours	 The shutdown of a generating unit or facility for inspection or maintenance, in accordance with an advance schedule; represented in hours per unit (Equivalent Planned Outage Hours). Planned Hours – hours provided in the Generation Outage Schedule for the following 90-day outlook. Actual Hours – number of hours a unit was out of service due to a planned outage. 	N/A – values is provided for each unit
Maintenance Outage Hours	The shutdown of a generating unit or facility for nonemergency reasons or conditions which need repair outside of the advance schedule; represented in hours per unit.	N/A – value is provided for each unit
Forced Outage Hours	The shutdown of a generating unit or facility for emergency reasons or a condition in which the generating equipment is unavailable for load due to unanticipated breakdown; represented in hours per unit.	N/A – value is provided for each unit
Forced Outage Rate	The ratio of the forced outages hours to the hours the unit was anticipated to be available for the reporting period.	Forced Outage Hours / Period Hours (excluding planned and unplanned outage hours)
Nameplate Capacity	The maximum rated output of a generator, prime mover, or other electric power production equipment under specific conditions designated by the manufacturer.	N/A – value is provided for each unit
Generation Shortfall Events	An event in which customer demand for electricity is unable to be met due to lack of Available Capacity, leading to customers being manually disconnected from the grid.	N/A – Value is all events which occur in a specified time frame
Unit Performance Load Shed Events	An event in which a generating unit has an unanticipated breakdown and causes customers to be automatically disconnected from the grid to prevent potential damage to the system.	N/A – Value is all events which occur in a specified time frame

Plant and Unit List – Baseload and Peaker Units

Plant Units V			BASELC	DAD UNI	TS						PEA	AKER UN	NITS					PE	AKER L	JNITS				
Image: A construction Image: Construction Sector	Plant	Units	System Reserves	System Availability	System Heat Rate	All Metrics for Baseload Units	All Metrics for Peaker Units	Renewables Capacity Factor	Plant	Units	System Reserves	System Availability	System Heat Rate	All Metrics for Baseload Units	All Metrics for Peaker Units	Renewables Capacity Factor	Plant	Units	System Reserves	System Availability	System Heat Rate	All Metrics for Baseload Units	All Metrics for Peaker Units	Renewables Capacity Factor
San Juan CT 6 X <thx< th=""> X <thx< td=""><td></td><td>CT 5</td><td>Х</td><td>Х</td><td>Х</td><td>Х</td><td></td><td></td><td></td><td>GT 1</td><td>Х</td><td>Х</td><td></td><td></td><td>Х</td><td></td><td></td><td>Daguao 1-1</td><td></td><td></td><td>Х</td><td></td><td></td><td></td></thx<></thx<>		CT 5	Х	Х	Х	Х				GT 1	Х	Х			Х			Daguao 1-1			Х			
San Juan STM 6 X		STM 5	Х	Х	Х	Х				GT 2	Х	Х			Х			Daguao 1-2	Х	Х	Х		Х	
San Juan		CT 6	Х	Х	Х	Х			FFN 4 A	GT 3	Х	Х			Х			Aguirre 2-1	Х	Х	Х		Х	
Image: constraint of the sector of	Con luon	STM 6	Х	Х	Х	Х				GT 4	Х	Х			Х			Aguirre 2-2	Х	Х	Х		Х	
9 X <td>San Juan</td> <td>7</td> <td>Х</td> <td>Х</td> <td>Х</td> <td>Х</td> <td></td> <td></td> <td>San Juan</td> <td>GT 5</td> <td>Х</td> <td>Х</td> <td></td> <td></td> <td>Х</td> <td></td> <td></td> <td>Costa Sur 1-1</td> <td>Х</td> <td>Х</td> <td>Х</td> <td></td> <td>Х</td> <td></td>	San Juan	7	Х	Х	Х	Х			San Juan	GT 5	Х	Х			Х			Costa Sur 1-1	Х	Х	Х		Х	
IndXX <t< td=""><td></td><td>8</td><td>Х</td><td>Х</td><td>Х</td><td>Х</td><td></td><td></td><td></td><td>GT 6</td><td>Х</td><td>Х</td><td></td><td></td><td>Х</td><td></td><td></td><td>Costa Sur 1-2</td><td>Х</td><td>Х</td><td>Х</td><td></td><td>Х</td><td></td></t<>		8	Х	Х	Х	Х				GT 6	Х	Х			Х			Costa Sur 1-2	Х	Х	Х		Х	
Costa Sur S X Palo Seco 3 X <td></td> <td>9</td> <td>Х</td> <td>Х</td> <td>Х</td> <td>Х</td> <td></td> <td></td> <td></td> <td>GT 7</td> <td>Х</td> <td>Х</td> <td></td> <td></td> <td>Х</td> <td></td> <td></td> <td>Jobos 1-1</td> <td>Х</td> <td>Х</td> <td>Х</td> <td></td> <td>Х</td> <td></td>		9	Х	Х	Х	Х				GT 7	Х	Х			Х			Jobos 1-1	Х	Х	Х		Х	
Costa Sur 5 X <		10	Х	Х	Х	Х				GT 8	Х	Х			Х		Othor		Х	Х			Х	
Costa Sur 6 X	6 h 6	5	Х	Х	Х	Х				GT 9	Х	Х			Х			Yabucoa 1-1	Х	Х	Х		Х	
Aguirre 1 X <t< td=""><td>Costa Sur</td><td>6</td><td>Х</td><td>Х</td><td>Х</td><td></td><td></td><td></td><td></td><td>GT 10</td><td>х</td><td>х</td><td></td><td></td><td>х</td><td></td><td>r cakers</td><td>Yabucoa 1-2</td><td>Х</td><td>Х</td><td>Х</td><td></td><td>Х</td><td></td></t<>	Costa Sur	6	Х	Х	Х					GT 10	х	х			х		r cakers	Yabucoa 1-2	Х	Х	Х		Х	
Againfre 2 X <		1	Х	Х	Х	Х				1-1	Х	Х	Х		Х				Х	Х	Х		Х	
Palo Seco 1 X <	Aguirre									1-2	Х	Х	Х		Х					Х				
Palo Seco 2 X <			Х							2-1	Х	Х	Х		Х			•						
Pailo Seco 3 X		2			х					2-2	Х	Х	Х		Х			•						_
4 x <td>Palo Seco</td> <td>3</td> <td></td> <td></td> <td>х</td> <td></td> <td></td> <td></td> <td></td> <td>3-1</td> <td>Х</td> <td>Х</td> <td>Х</td> <td></td> <td>Х</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td>	Palo Seco	3			х					3-1	Х	Х	Х		Х									
AES X <t< td=""><td></td><td>4</td><td></td><td></td><td>х</td><td></td><td></td><td></td><td></td><td>3-2</td><td>Х</td><td>Х</td><td>Х</td><td></td><td>Х</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></t<>		4			х					3-2	Х	Х	Х		Х									
AES X<		AES 1	_						Packj	MP 1	Х	Х	Х		Х									
EcoEléctrica ECO 1 X <td>AES</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>MP 2</td> <td>Х</td> <td>Х</td> <td>Х</td> <td></td> <td>Х</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td>	AES									MP 2	Х	Х	Х		Х									
EcoEléctrica ECO 2 X <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>MP 3</td> <td>Х</td> <td>Х</td> <td>Х</td> <td></td> <td>Х</td> <td></td> <td>Cambalache</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td>										MP 3	Х	Х	Х		Х		Cambalache							
STM 1 X	EcoEléctrica									I-1	Х	Х	Х		Х									
FEMA GT 4 X <t< td=""><td></td><td></td><td></td><td>X</td><td>X</td><td></td><td></td><td></td><td></td><td>I-2</td><td>Х</td><td>Х</td><td>Х</td><td></td><td>Х</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></t<>				X	X					I-2	Х	Х	Х		Х									
FEMA GT 4 X <t< td=""><td></td><td>011111</td><td>~</td><td>~</td><td>~</td><td>A</td><td></td><td></td><td></td><td>I-3</td><td>Х</td><td>Х</td><td>Х</td><td></td><td>Х</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></t<>		011111	~	~	~	A				I-3	Х	Х	Х		Х									
Aguirre CC Aguirre CC <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>1-4</td> <td>Х</td> <td>Х</td> <td>Х</td> <td></td> <td>Х</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td>										1-4	Х	Х	Х		Х									
GT 1 X X X X GT 2 X X X GT 2 X X X GT 4 X X X Mathematical Sector II-1 X X X X X X X II-2 X X X X X X X X X II-3 X X X X X X X X X II-4 X X X X X X X X X			PEAK	ER UNIT	S				Aguirro CC	ST-1	Х	Х	Х		Х		Mavaguez							
GT 2 X		CT 1	V	v	-		V		Aguirre CC	II-1		Х	Х		Х									
FEMA GT 4 X X X X A </td <td></td> <td></td> <td>X</td> <td>X</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>Х</td> <td>Х</td> <td></td> <td>Х</td> <td></td> <td></td> <td>-</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td>			X	X								Х	Х		Х			-						
	FEN4 0		-							II-3	Х	Х	Х		Х								X	
										11-4	Х	Х	Х		Х			4B	Х	Х	Х		Х	
	Palo Seco		-							ST-2	Х	Х	Х		Х									

GT 6 GT 7

Х

Plant and Unit List – Renewable Projects

SOLAR PROJECTS								HYDRO PLANTS												
Projects	System Reserves	System Availability	System Heat Rate	All Metrics for Baseload Units	All Metrics for Peaker Units	Renewables Capacity Factor	Projects	System Reserves	System Availability	System Heat Rate	All Metrics for Baseload Units	All Metrics for Peaker Units	Renewables Capacity Factor	Projects	System Reserves	System Availability	System Heat Rate	All Metrics for Baseload Units	All Metrics for Peaker Units	Renewables Capacity Factor
AES Ilumina						x	Pattern Santa						х	Caonillas 1-1						
						~	Isabel						Λ	Caonillas 1-2						
Cantera Martinó							-						х	Caonillas 2-1						
						Х	Punta Lima							Dos Bocas 1						
San Fermín							Landfill Gas							Dos Bocas 2						
						Х	Fajardo						Х	Dos Bocas 3						
							-							Garzas 1-1						
Horizon Energy						x	Landfill Gas						Х	Garzas 1-2						
							Тоа Ваја							Garzas 2-1 Patillas 1-1						
						V								Patillas 1-1 Patillas 1-2						
Oriana Energy						Х								Rio Blanco 1-1						
														Rio Blanco 1-1						
Coto Laurel						Х								Toro Negro 1-1						
														Toro Negro 1-2						
Humacao						х								Toro Negro 1-3						
														Toro Negro 1-4						
														Toro Negro 2-1						
														Yauco 1-1						
														Yauco 2-1						
														Yauco 2-2						