

Monthly Generation Performance Report December 2024

Introduction

This report oversees Puerto Rico's electrical system overall performance; from system level to unit's level. System level measures shown are generation, availability and reserves level. Additionally, a summary of load shed events occurred in the last 12 months prior to this report's month. At plant and unit level, it oversees generation, availability, heat rate, and outage hours (planned, maintenance and forced). Finally, in terms of economics, fuel and variable costs are shown.

As part of the Transmission and Distribution System Operation and Maintenance Agreement (OMA), LUMA serves as both the operator of the electric grid and as the island's System Operator.

As the Operator of the electric grid, LUMA oversees and maintains the transmission and distribution system that is critical to delivering energy to over 1.5 million Puerto Rican customers.

As the System Operator, LUMA monitors the performance of Genera PR and other private generators' generation units, implements dispatch of available units, and plans and maintains adequate generation reserve levels to meet customer's energy demands.

While LUMA does not generate energy, LUMA's responsibility as the System Operator includes measuring the performance of the island's generation fleet. This report summarizes generation performance, identifies trends, compares facility performance, and provides a high-level picture of the entire generation portfolio.



Table of Contents

Operations

- System Level Performance
 - System Reserve Status
 - o System Heat Rate
 - System Availability
 - Load Shed Events
- Plant Level Performance
 - o Available Capacity
 - o Heat Rate
 - o Generation and Capacity Factor
 - Planned Outage Hours
 - Maintenance Outage Hours
 - Forced Outage Hours
 - Renewables Capacity Factor

Economics

- Fuel Prices
- Fuel Production Costs

About This Report

- Glossary of Terms
- Plant and Unit List



Confidential. Do not distribute.

Executive Summary

December 2024 performance

Overview

The maximum peak demand for December 2024 was approximately 2,512 MW.

San Juan 6 (220 MW) is currently offline and is expected to return to service on May 31, 2025. San Juan 7 (100 MW) is currently offline, and the expected date of return is May 31, 2025. San Juan 9 (100 MW) is offline and is expected to return on January 21, 2025. Aguirre 1 & Aguirre 2 (450 MW each) are currently offline, Aguirre 1 is expected to return the first week of January, and Aguirre 2 is expected to return on January 24, 2024. Palo Seco 4 (216 MW) is expected to return to service by June 30, 2025

Major Events

In December, the electric system experienced 7 generation events that led to load shedding, with 6 caused by underfrequency due to generation unit trips and 1 caused by a generation shortfall event.

For December, the hourly reserve levels averaged 934 MW, with 211 hours during the month having less than 750 MW in reserves (equal to 28% of the time.)

The forecast for January 2025 shows fewer reserve levels to the same month this year (January 2024), with 561 MW average reserves forecasted versus 711 MW seen for the same month this year.

The System Availability for the month of December was 47%.

- Genera 39%
- AES 95%
- EcoEléctrica 98%



Confidential. Do not distribute.

Operations System-Level Performance

System Reserves


∢

LUM,

Actual reserves timeframe: January 2024 – December 2024 Forecasted reserves timeframe: January 2025 – March 2025

System Reserves is the amount of generating capacity available to meet peak or abnormally high demands for power and to generate power during scheduled or unscheduled outages.


Target: 🔺 Reserves >750MW per the System Operation Principles



System Availability

The System Availability is the maximum expected output that generating units can supply to system load, adjusted for scheduled or unscheduled outages. In this graph, the availability is being compared with the total generation required to meet demand to visualize the gap between the two lines (the gap represents the reserves level).

Target: A bigger gap between availability and generation demand means a better chance of recovery in emergency events due to adequate reserves.



System Heat Rate

The System Heat Rate measures the efficiency of the system to convert fuel into electricity. System Heat Rate will vary depending on the available generation units and required resources to satisfy electrical demand. It is calculated as energy consumed (MMBtu) / energy produced (MWh). The forecasted Heat Rate is determined by the last forecast calculated for the Fuel Clause Adjustment Factor.

Target: **V** Lower heat rates represent higher efficiency.




Forecasted vs Actual System Heat Rate

Load Shed Events

Load shed events can occur due to unexpected generation unit losses (Unit Performance Load Shed Events). Also, when the demand for electricity exceeds available supply levels, LUMA, as the system operator and in compliance with its responsibilities under the T&D OMA, implements load shedding to stabilize the electric system and prevent larger and longer outages (Generation Shortfall Events).

LUMA does not generate energy and can only operate the system with the electricity that is provided by Genera PR, PREPA, and other island generators.



Operations Plant/Units-Level Performance

Available Capacity – Baseload Units

Available Capacity is the maximum output that a unit can generate at any given time. The Availability Rate indicates the percent of available capacity out of the total nameplate capacity. Variables in the chart below are shown in MW (gross) representing an average over the month.

Target: A higher availability indicates the plant is able to produce power closer to its nameplate capacity.

	Available Cap	acity (MW) and /	Availat	ility Rate (AR)	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24
AES	510 255	$\overline{}$					370	330	463	406	249	257	440	466	371	364	353	484
Nameplate Cap: 508	JFI	мам	1 1	A S	ONI		¥ 73%	65%	91%	80%	49%	51%	87%	92%	73%	72%	69%	95%
EcoElectrica	275			\checkmark			550	547	550	550	543	566	566	252	391	561	566	556
Nameplate Cap: 566	JFI	мам	1_1	A S	ONI		¥ 100%	99%	100%	100%	99%	100%	100%	45%	69%	99%	100%	98%
Genera Aguirre	900		~		_		210	368	341	303	505	592	440	314	147	169	220	0
Nameplate Cap: 900		мам	ı ı	A S	ONI		¥ 23%	41%	38%	34%	56%	66%	49%	35%	16%	19%	24%	0%
Genera Costa Sur	500						48	3	105	316	403	533	599	546	643	561	574	525
Nameplate Cap: 990	0 J F M	MAM]]	A S	O N D	:	¥ 5%	0%	11%	32%	41%	54%	60%	55%	65%	57%	58%	53%
Genera Palo Seco	602			_			0	0	0	0	0	0	27	173	198	193	146	162
Nameplate Cap: 602	- , , ,	мам	1 1	A S	ONI		¥ 0%	0%	0%	0%	0%	0%	4%	29%	33%	32%	24%	27%
Genera San Juan	840	_					543	429	425	250	266	330	392	398	375	259	254	205
Nameplate Cap: 840		мам	1 1	A S	ONI		₩ 65%	51%	51%	30%	32%	39%	47%	47%	45%	31%	30%	24%
Total Baseload	4600						2069	2021	1884	1826	1967	2279	2462	2149	2125	2108	2113	1931
Nameplate Cap: 4236		мам	1 1	A S	S O N I		¥ 43%	42%	43%	41%	45%	52%	56%	49%	48%	48%	48%	44%

Available Capacity – Peaker Units

Available Capacity is the maximum output that a unit can generate at any given time. The Availability Rate indicates the percent of available capacity out of the total nameplate capacity. Variables in the chart below are shown in MW (gross) representing an average over the month.

Target: A higher availability indicates the plant is able to produce power closer to its nameplate capacity.

А	vailal	able	Capa	city	(MW	/) and	d Av	/ailat	oility	Rate (A	R)	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24
Genera Aguirre Combined Cycle	592 296										MM	150	138	127	170	178	201	197	206	216	257	239	246
Nameplate Cap: 592	0	1	F	м	M	1	J	А	s o	N D	AR	25%	23%	21%	29%	30%	34%	33%	35%	37%	43%	40%	42%
Genera Cambalache	248 124 0	-							_	\checkmark	MM	152	156	153	155	155	151	151	152	155	152	106	149
Nameplate Cap: 248	U	L	F	м	A M	1	J	А	s o	N D	AR	62%	63%	62%	63%	63%	61%	61%	61%	63%	61%	43%	60%
Genera Mayaguez	220 110 0	_		_	_						MM	183	182	176	151	165	153	140	141	140	135	143	138
Nameplate Cap: 220	0	, T	F	м	M	1	J	А	s o	N D	AR	83%	83%	80%	69%	75%	69%	64%	64%	64%	61%	65%	63%
Genera Palo Seco Mobile-Packs	82 41 0		,	/	1				1		MM	3	0	1	71	74	72	70	69	73	73	74	78
Nameplate Cap: 81		1	F N	A N	М	1	J	A S	5 0	N D	AR	3%	0%	1%	87%	92%	89%	87%	85%	90%	90%	92%	96%
Palo Seco TM	150 75 0			-	_						MM	147	143	96	62	80	86	84	87	79	82	90	83
Nameplate Cap: 90		1	F	м	M	1	J	А	s o	N D	AR	98%	95%	80%	69%	89%	96%	93%	97%	88%	91%	99%	93%
San Juan TM	250 125 0	_	_	~						_	MM	201	200	205	245	236	226	224	218	239	212	221	200
Nameplate Cap: 250		1	F	M	A M	1	1	А	s o	N D	AR	101%	100%	91%	98%	95%	91%	89%	87%	96%	85%	88%	80%
Other Peakers (Frame 5's)	380 190 0	_									MM	95	101	121	108	102	107	103	97	108	112	126	117
Nameplate Cap: 378		1	F	M	A M	, T	1	A	s o	N D	AR	25%	27%	32%	29%	27%	28%	27%	26%	29%	30%	33%	31%
Total Peakers	1860 930		_								MM	584	577	880	962	991	997	969	969	1010	1023	999	1013
Nameplate Cap: 1859	0		F	м	M	1	J.	A	0	N D	AR	38%	38%	47%	52%	53%	54%	52%	52%	54%	55%	54%	54%

Heat Rate – Baseload Units

Heat Rate measures the efficiency of a power plant to convert fuel into electricity. It is calculated as energy consumed (MMBtu) / energy produced (MWh).

Target: **V** Lower heat rates represent higher efficiency.

		Heat Rate (MMBtu/MWh)	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24
AES	6,000 0	J F M A M J J A S O N D	9,800	9,800	10,620	10,620	10,620	10,620	10,620	10,620	10,620	10,620	10,620	10,620
EcoElectrica	0		7,957	7,957	7,957	7,957	7,881	7,881	7,881	7,881	7,881	7,881	7,881	7,881
Genera Aguirre	6,000 0	J F M A M J J A S O N D	11,207	11,397	11,268	11,117	10,934	10,951	11,220	11,225	11,142	11,177	10,813	-
Genera Costa Sur	6,000 0		11,323	40,045	11,913	10,397	10,703	10,562	10,343	10,854	10,738	10,976	11,075	11,052
Genera Palo Seco	0		-	-	-	-	-	-	10,264	9,696	9,648	9,296	9,669	9,817
Genera San Juan	6,000 0	J F M A M J J A S O N D	8,973	9,432	8,714	8,882	8,796	10,188	10,817	11,016	9,485	9,263	9,486	8,166
Total Baseload	12,000 6,000 0		8,968	9,381	9,510	9,564	9,687	9,904	10,007	10,275	9,817	9,761	9,807	11,459

Heat Rate – Peaker Units

Heat Rate measures the efficiency of a power plant to convert fuel into electricity. It is calculated as energy consumed (MMBtu) / energy produced (MWh).

Target: **V** Lower heat rates represent higher efficiency.

	Heat Rate (MMBtu/MWh)	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24
Genera Aguirre Combined Cycle	18,000 12,000 6,000 0 J F M A M J J A S O N D	14,671	14,989	13,867	11,936	11,751	12,482	13,852	11,888	12,289	11,844	12,793	12,276
Genera Cambalache	18,000 12,000 6,000 0 J F M A M J J A S O N D	12,834	12,785	12,872	12,640	12,407	12,756	12,876	12,361	12,343	12,361	13,227	12,818
Genera Mayaguez	18,000 12,000 6,000 0 J F M A M J J A S O N D	10,882	10,945	11,029	11,107	10,882	11,040	10,832	10,908	10,868	10,861	10,898	10,817
Genera Palo Seco (Inc. Mobile Packs)	18,000 12,000 6,000 0 J F M A M J J A S O N D	15,146	16,487	15,205	14,397	13,787	13,445	13,662	12,270	12,669	12,033	12,455	12,532
Palo Seco TM & San Juan TM	18,000 12,000 6,000 0 J F M A M J J A S O N D	-	-	-	11,706	11,137	11,032	10,961	10,983	10,993	11,534	11,255	10,991
Other Peakers	18,000 12,000 6,000 0 J F M A M J J A S O N D	15,064	15,462	14,062	12,730	15,043	14,990	6,912	14,031	14,563	13,000	12,653	8,022
Total Peakers	18,000 12,000 6,000 0 J F M A M J J A S O N D	12,755	12,951	12,710	5,416	6,168	5,087	4,468	6,354	6,246	6,525	4,333	11,395

Generation and Capacity Factor – Baseload Units

Generation indicates the average amount of energy each plant produced per month, in MW (gross). The Capacity Factor measures what percentage of the nameplate capacity was used to produce energy during that time period.

Target: A Higher Capacity Factor, and a Generation closer to the nameplate capacity will represent a better utilization of the units.

	Average Generation (MW) and Capacity Factor		Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24
AES	508	MM	355	320	452	412	249	251	437	449	357	365	348	481
Nameplate Cap: 508	J F M A M J J A S O N D	сĿ	70%	63%	89%	81%	49%	49%	86%	88%	70%	72%	68%	95%
EcoElectrica		MW	412	405	398	412	399	415	412	235	292	404	391	378
Nameplate Cap: 566	JFMAMJJASOND	СЕ	75%	74%	72%	75%	71%	73%	73%	42%	52%	71%	69%	67%
Genera Aguirre	900	MW	134	284	243	221	418	466	346	237	125	148	198	0
Nameplate Cap: 900	J F M A M J J A S O N D	сь	15%	32%	27%	25%	46%	52%	38%	26%	14%	16%	22%	0%
Genera Costa Sur	1000	MW	37	1	101	270	358	486	482	435	543	495	492	432
Nameplate Cap: 990	J F M A M J J A S O N D	Ч	4%	0%	10%	27%	36%	49%	49%	44%	55%	50%	50%	44%
Genera Palo Seco	602 301	MM	0	0	0	0	0	0	28	139	150	150	121	121
Nameplate Cap: 602	JFMAMJJASOND	Ч	0%	0%	0%	0%	0%	0%	5%	23%	25%	25%	20%	20%
Genera San Juan	840 420	MM	473	380	380	227	254	306	343	302	330	229	211	180
Nameplate Cap: 840	JFMAMJJASOND	GF	56%	45%	45%	27%	30%	36%	41%	36%	39%	27%	25%	21%
Total Baseload	4410	MW	1763	1735	1573	1542	1679	1924	2047	1798	1797	1790	1761	1593
Nameplate Cap: 4406	JFMAMJJASOND	СЕ	37%	36%	36%	35%	38%	44%	46%	41%	41%	41%	40%	36%

Generation and Capacity Factor – Peaker Units

Generation indicates the average amount of energy each plant produced per month, in MW (gross). The Capacity Factor measures what percentage of the nameplate capacity was used to produce energy during that time period.

Target: A Higher Capacity Factor, and a Generation closer to the nameplate capacity will represent a better utilization of the units.

	Average Generation (MW) and Capacity Factor		Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24
Genera Aguirre Combined Cycle	592	MM	49	42	31	79	101	75	48	114	120	149	58	85
Nameplate Cap: 592	JFMAMJJASOND	сE	8%	7%	5%	13%	17%	13%	8%	19%	20%	25%	10%	14%
Genera Cambalache	248	MM	31	35	24	57	71	37	27	67	74	68	19	42
Nameplate Cap: 247.5	JFMAMJJASOND	СF	13%	14%	10%	23%	29%	15%	11%	27%	30%	27%	8%	17%
Genera Mayaguez	220	MM	77	72	56	79	90	66	49	69	68	66	45	57
Nameplate Cap: 220	JFMAMJJASOND	сĿ	35%	33%	25%	36%	41%	30%	22%	31%	31%	30%	20%	26%
Genera Palo Seco Mobile-Packs	82	MM	1	0	1	4	12	10	2	22	18	19	7	10
Nameplate Cap: 81	JFMAMJJASOND	сE	1%	0%	1%	5%	14%	12%	3%	27%	23%	23%	8%	12%
Palo Seco TM	150	MM	151	143	96	66	82	85	60	80	77	80	79	71
Nameplate Cap: 90	JFMAMJJASOND	GF	101%	95%	80%	74%	91%	94%	66%	89%	85%	89%	87%	79%
San Juan TM	250	MM	201	201	189	241	222	203	179	180	217	193	170	179
Nameplate Cap: 250	JFMAMJJASOND	сF	101%	101%	84%	96%	89%	81%	71%	72%	87%	77%	68%	72%
Other Peakers (Frame 5's)	378	MW	20	21	22	26	42	18	15	29	32	33	8	13
Nameplate Cap: 378	JFMAMJJASOND	СE	5%	6%	6%	7%	11%	5%	4%	8%	8%	9%	2%	4%
Total Peakers	930	MM	178	171	418	552	620	494	379	561	605	608	385	459
Nameplate Cap: 1859	J F M A M J J A S O N D	сE	12%	11%	22%	30%	33%	27%	20%	30%	33%	33%	21%	25%

Planned Outage Hours – Baseload Units

Planned Outage Hours represents the shutdown of a generating unit or facility for inspection or maintenance, in accordance with an advance schedule; represented in hours. This scoreboard compares the scheduled outage hours with the actual duration of the outage.

Target: ▼ A smaller gap between actuals and planned hours represents a more accurate planification.

	Planned Outage Hou (JAN 2024 - DEC 2024		Completed urs Outage Hours	Notes for In-Progress Planned Outages	Expected Return-to- Service Date
AES	Completed Planned 0 1000	2000	908		
EcoElectrica	Completed Planned 0 200 400	432	253		
Genera Aguirre	Completed Planned 0 1000	2000	0		
Genera Costa Sur	Completed Planned 0 1000	2000	0		
Genera Palo Seco	Completed Planned 0 2000	4000	935		
Genera San Juan	Completed Planned 0 5000 10000	10104	748		
Total Baseload	Completed Planned 0 10000 20000	19320	3113		

Forced Outage Hours and Rate – Baseload Units

Forced Outage Hours represent the shutdown of a generating unit or facility for emergency reasons or a condition in which the generating equipment is unavailable for load due to an unanticipated breakdown; represented in hours per unit. The Forced Outage Rate represents the percentage of time the unit was in a Forced Outage condition out of the total time the unit was expected to be available.

Target: V Less forced outage hours and a smaller outage rate represents more available capacity in the system to meet demand.

	Forced Outage Hours and Outage Rate		Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24
AES	100% 50%	Hrs	308	445	0	92	168	93	88	0	316	327	365	0
	JFMAMJJASOND	%	21%	32%	0%	6%	17%	11%	6%	0%	22%	22%	25%	0%
EcoElectrica	100%	Hrs	0	7	0	0	65	0	0	1048	344	28	0	56
	JFMAMJJASOND	%	0%	0%	0%	0%	3%	0%	0%	47%	18%	1%	0%	2%
Genera Aguirre	100%	Hrs	1024	395	697	866	324	101	361	632	1061	1032	881	336
	JFMAMJJASOND	%	69%	28%	47%	60%	22%	7%	24%	42%	74%	69%	61%	23%
Genera Costa Sur	100%	Hrs	1391	1373	1094	720	338	149	201	263	0	102	0	73
	JFMAMJJASOND	%	47%	49%	37%	26%	11%	5%	7%	9%	0%	3%	0%	2%
Genera Palo Seco	100%	Hrs	2854	2662	2806	2782	2638	2782	2758	2246	2159	2278	2178	1084
	JFMAMJJASOND	%	100%	100%	97%	100%	100%	100%	94%	77%	75%	77%	76%	36%
Genera San Juan	100%	Hrs	1561	2221	2013	3908	3718	3702	3673	3703	2957	3836	3875	1594
	JFMAMJJASOND	%	26%	42%	36%	68%	63%	65%	63%	62%	52%	67%	70%	27%
Total Baseload	100%	Hrs	7869	8248	6610	8368	7251	6827	7082	7892	6837	7604	7298	3143
	JFMAMJJASOND	%	27%	30%	42%	55%	46%	45%	45%	51%	45%	49%	48%	20%

Renewables Capacity Factor – Solar

The Capacity Factor measures the actual production of electricity over the theoretical maximum output (nameplate capacity). For Renewable projects, the Capacity Factor is expected to be lower due to the solar and wind cycles.

Target: A higher Capacity Factor represents a better utilization of the maximum capacity the project is able to produce.

	_	Av	erage	e Pro	duct	ion (I	MW)	and	Cap	acity Fa	ctor	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24
AES Ilumina	20 10										MW	4	3	4	4	4	4	4	4	4	4	3	3
Nameplate Cap: 20	0	1	F M	1 A	М	1	1	A S	0	N D	СЕ	19%	17%	21%	20%	20%	19%	19%	19%	19%	18%	15%	15%
Windmar Cantera Martinó	2.0 1.0										MM	0.4	0.4	0.5	0.5	0.4	0.4	0.3	0.3	0.3	0.2	0.3	0.2
Nameplate Cap: 2.1	0.0	J	F M	A	М	J	1	A 5	0	NE	CF C	21%	18%	25%	22%	20%	19%	14%	14%	13%	11%	13%	9%
San Fermín	20 10										MM	2	2	2	2	1	1	1	2	1	1	1	1
Nameplate Cap: 20	0	J	F M	1 A	М	٦	1	A S	0	N D	CF	10%	9%	12%	10%	7%	7%	7%	8%	7%	7%	5%	5%
Horizon Energy	10 5										MM	2	2	3	3	3	3	3	3	3	2	2	2
Nameplate Cap: 10	0	J	F M	1 A	М	1	J	A S	0	N D	С	25%	22%	27%	26%	27%	26%	26%	27%	26%	24%	23%	22%
Oriana Energy	40 20	_									MM	10	10	10	11	10	11	10	11	10	9	8	8
Nameplate Cap: 45	0	J	F M	1 A	М	٦	1	A S	0	N D	ц	22%	21%	23%	24%	23%	24%	22%	24%	23%	21%	17%	18%
Windmar Coto Laurel	10 5										MM	2	2	2	2	2	1	1	2	1	1	2	2
Nameplate Cap: 10	0	L	F M	1 A	М	٦	1	A S	0	N D	сĿ	16%	16%	19%	19%	18%	15%	14%	16%	10%	14%	17%	16%
Fonroche Humacao	40 20										MM	7	7	9	8	8	7	7	9	8	6	6	6
Nameplate Cap: 40	0	J	F M	1 A	М	1	1	A S	0	N D	СЕ	16%	17%	21%	19%	20%	18%	18%	21%	20%	14%	14%	16%
Total Solar	140 70	_									MM	27	26	31	29	29	27	27	29	27	24	22	23
Nameplate Cap: 147	0	1	F P	M A	M	J	J	A S	; 0	N D	сĿ	18%	17%	21%	20%	19%	19%	18%	20%	19%	16%	15%	15%

Renewables Capacity Factor – Wind and Landfill

The Capacity Factor measures the actual production of electricity over the theoretical maximum output (nameplate capacity). For Renewable projects, the Capacity Factor is expected to be lower due to the solar and wind cycles.

Target: A higher Capacity Factor represents a better utilization of the maximum capacity the project is able to produce.


		Avera	ige Pi	rodu	iction	(M	W) a	nd	Сара	acity	y Fact	or	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24
Pattern Santa Isabel	74 37 0											MM	17	10	13	12	12	16	22	18	12	6	7	9
Nameplate Cap: 95	-	J F	М	А	М	J	J A	l	s c		N D	CF	22%	13%	14%	13%	13%	17%	23%	18%	13%	6%	7%	10%
Punta Lima	26 13 0			_			~					MW	6	4	5	6	3	5	9	6	3	2	3	5
Nameplate Cap: 26	Ŭ	J F	М	А	М	J	J A	l	s c		ND	СЕ	25%	14%	20%	25%	12%	20%	33%	23%	12%	8%	11%	18%
Landfill Gas Fajardo	2.4 1.2 0.0									_		MM	0.2	0.0	0.0	0.1	0.1	0.0	0.1	0.0	0.1	0.8	0.47	0.5
Nameplate Cap: 2.4	0.0	J F	M	А	Μ	J	J A	ł	s c		N D	Ч	10%	0%	0%	5%	5%	0%	4%	2%	4%	33%	19%	21%
Landfill Gas Toa Baja	2.4 1.2 0.0			_		_	~					MW	1.0	1.0	1.0	1.1	0.9	0.8	1.2	0.5	0.4	0.0	0.5	0.66
Nameplate Cap: 2.4	0.0	J F	M	А	Μ	J	J A	ł	s c		N D	Ч	42%	43%	41%	47%	36%	33%	48%	21%	15%	1%	21%	27%
Total Wind and Landfill	80 40 0											MM	24	14	20	20	16	22	32	24	16	8	10	15
Nameplate Cap: 80		J F	М	А	М	J	J A	l.	s c		N D	Ч	23%	14%	16%	16%	13%	18%	25%	19%	13%	7%	8%	12%

Economics

LUMA


Fuel Prices

Fuel Price shows the prices paid for fuel used by PREPA and private generators, both in terms of MMBtus and Barrel of Oil Equivalent (BOE). The Fuel Price is divided by Fuel Type to better illustrate the contribution to the total Fuel Price for the month.



Variable Production Costs

Variable Production Costs are predominantly fuel costs and reflect the cost to produce one MWh of energy. In the graph, the cost is shown separately for Baseload units and Peaker units. The weighted average cost indicates the cost per MWh of energy produced for the System Portfolio.



	Dec-23	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24
Base Load	\$78	\$69	\$77	\$93	\$92	\$117	\$123	\$122	\$118	\$110	\$106	\$99	\$98
Peaker	\$293	\$275	\$279	\$138	\$204	\$198	\$188	\$185	\$189	\$179	\$187	\$169	\$170
	\$113	\$108	\$117	\$103	\$123	\$139	\$137	\$132	\$135	\$127	\$126	\$112	\$114

Base Load Peaker System Total

Appendix

Glossary of Terms

Term	Definition	Formula
Heat Rate	Measures the efficiency of a power plant to convert fuel into electricity. It is the amount of energy used by a power plant to generate one kilowatt-hour (kWh) of electricity. The more efficient the generator is, the lower the heat rate.	MMBtu consumption by all units in the station during a specific period / MWh produced by the same units in the same period
Reserves	Amount of generating capacity available to meet peak or abnormally high demands for power and to generate power during scheduled or unscheduled outages.	Available Capacity (MW) during the reported period minus the Actual Generation (MW) during the same period
Available Capacity	The maximum output, commonly expressed in megawatts (MW), that generating equipment can supply to system load, adjusted for scheduled or unscheduled outages.	N/A – value is provided for each unit
Availability Rate	The ratio of the maximum output that can be supplied to system load for the period of time considered to the nameplate capacity.	Average available capacity for a specific period (MW) / nameplate capacity
Production	The amount of electric energy produced.	N/A – value is provided for each unit
Capacity Factor	The ratio of the electrical energy produced by a generating unit for the period of time considered to the nameplate capacity.	The average energy produced by all units in the plant during a specific period (MWh) / Nameplate capacity for the plant
Planned Outage Hours	 The shutdown of a generating unit or facility for inspection or maintenance, in accordance with an advance schedule; represented in hours per unit (Equivalent Planned Outage Hours). Planned Hours – hours provided in the Generation Outage Schedule for the following 90-day outlook. Actual Hours – number of hours a unit was out of service due to a planned outage. 	N/A – values is provided for each unit
Maintenance Outage Hours	The shutdown of a generating unit or facility for nonemergency reasons or conditions which need repair outside of the advance schedule; represented in hours per unit.	N/A – value is provided for each unit
Forced Outage Hours	The shutdown of a generating unit or facility for emergency reasons or a condition in which the generating equipment is unavailable for load due to unanticipated breakdown; represented in hours per unit.	N/A – value is provided for each unit
Forced Outage Rate	The ratio of the forced outages hours to the hours the unit was anticipated to be available for the reporting period.	Forced Outage Hours / Period Hours (excluding planned and unplanned outage hours)
Nameplate Capacity	The maximum rated output of a generator, prime mover, or other electric power production equipment under specific conditions designated by the manufacturer.	N/A – value is provided for each unit
Generation Shortfall Events	An event in which customer demand for electricity is unable to be met due to lack of Available Capacity, leading to customers being manually disconnected from the grid.	N/A – Value is all events which occur in a specified time frame
Unit Performance Load Shed Events	An event in which a generating unit has an unanticipated breakdown and causes customers to be automatically disconnected from the grid to prevent potential damage to the system.	N/A – Value is all events which occur in a specified time frame

La gente primero. La seguridad siempre.

