



Document Title:

SM-4 Fuse Refill for S&C Fuse Holder

Document Type:

Specification

Engineering Type

Material Specification

Document No.:

4350.144

Department

Distribution

Version:

03

Effective Date:

Sep 11, 2024

Shared document with: N/A

**Select the Departments impacted by the document*

For others, specify here

Author

Rodolfo A. Flores Ortiz, PE (Lic. 27131)
General Engineer, Distribution Standards & Materials

Signature and Date

Sep 11, 2024

Reviewer

Miguel J. Rios López, PE (Lic. 16636)
General Engineer, Distribution Standards & Materials

Signature and Date

Sep 11, 2024

Approver

Ricardo Castro Gómez, PE (Lic. 12135)
Manager, Distribution Standards & Materials

Signature and Date

Sep 11, 2024

Management Approval (If apply)

Approver

Name
Position

Signature and Date

N/A

Related/Referenced Documents

N/A

Version History

Version	Date	Revision Comments
1	Dec. 21, 2021	PREPA to LUMA format
2	Jul. 07, 2022	General revision and table of compliance created.
3	Sep. 11, 2024	General format modifications, TOC updated, Section 4 modified, and sections order rearranged.



Item Version History

Warehouse Catalog #	Asset Suite #	Version	Date
010-03813	55877	7	09/11/2024
010-03839	55878	6	09/11/2024
010-03854	55879	6	09/11/2024
010-03870	55880	5	09/11/2024
010-03896	55881	5	09/11/2024



1. Introduction

This specification describes the minimum requirements for the SM-4 fuse refill for S&C fuse holder used in the distribution system in Puerto Rico. Further information will be provided by LUMA Energy at the time of order placement and will provide information on site specific conditions, quantity, and other requirements. This document includes the general electrical and mechanical characteristics of the equipment/material.

2. Special Requirements

Samples shall be furnished as requested by LUMA Energy. Vendors that have supplied this equipment/material to LUMA on previous orders will not have to furnish samples at bid opening. The equipment/material will be received at the LUMA's general warehouse (O11) at Palo Seco, Puerto Rico. Shipping will include transportation and unloading at the indicated warehouse.

3. Literature

- 3.1. Descriptive and technical literature must be supplied by the vendor at time of bidding. This literature must include, but is not limited to details of material, drawings, documented testing, and instructions for use and installation. **The literature must be an official document from and certified by the manufacturer.** Failure to submit documents on time and duly certified by the manufacturer will cause bidder disqualification.
- 3.2. If required by LUMA, final drawings and documentation shall be submitted by the vendor before the manufacturing and shipping process for approval.

4. Compatible with

For compatible manufacturers and models, see Table 1. These models are examples of the equipment/materials described in this document and do not represent a preference. LUMA will evaluate equally any models not listed here during any acquisition event.

5. Markings

- 5.1. Containers shall be marked outside with LUMA Energy's purchase order and item number.
- 5.2. Package(s) to be delivered at warehouse shall be clearly marked with manufacturer and item information (part number, serial number, quantity, etc.)
- 5.3. Packaging labels and tags shall be waterproof.

6. Packaging

All equipment/material shall be packaged and marked in such a way as to facilitate handling and protection from damage and that the receiving warehouse can readily identify it and send it, in one complete unit, to a field location without opening crates or boxes to sort items and/or parts.

7. Number Per Package (Logistics)

Twenty-Five (25) unit per box or as requested by LUMA Energy.

8. Acceptance Criteria

- 8.1. Test required: certified by external laboratories.
- 8.2. Product shall be manufactured in accordance with the latest issue below (section 8.3). When conflicts occur between purchaser's specifications and the latest issue below, the purchaser's specification shall prevail.
- 8.3. Latest applicable codes, standards, and other regulations:
 - a. IEEE C37.41 – Standard design tests for high-voltage (>1000 V) fuses and accessories
 - b. IEEE C37.42 - Specifications for high voltage (above 1000 volts) Class A and Class B expulsion and current-limiting fuses.
- 8.4. If any other standard different from the ones indicated in this document are used, the supplier must provide information showing compatibility with the required ones.

9. Description

- 9.1. The SM-4 power fuse refill for S&C SM-4 fuse holder consists of a fusible element, arcing rods, and a solid-material arc-extinguishing medium contained within a filament-wound glass-epoxy tube.
- 9.2. This unit are especially suited for protecting transformers, capacitor banks, and cables in outdoor distribution substations.
- 9.3. Shall be designed in accordance with the minimum melting time characteristic curve TCC 153-4 for standard speed.
- 9.4. Nominal operating voltage: 14.4 KV
- 9.5. Maximum Interrupting Current (symmetrical): 12,500 A.
- 9.6. For models and ratings see Table 1.

10. Inspection

The acceptance of any equipment/material shall in no way relieve the vendor from his responsibility to meet all the requirements of this specification, and it would not prevent subsequent rejection if such equipment/materials were found later to be defective.



11. Proposal Information

11.1. Submitted proposals must include:

- a. Technical information, tests, and drawings.
- b. Table of Compliance completed by the bidder with reference (see Appendix 1).

12. Table 1: Warehouse and Asset Suite Identification Number

Warehouse Catalog #	Asset Suite #	Continuous Current Rating (A)	Compatible Manufacturer	Model
010-03854	55879	25	S&C Electric Company	122040R4
010-03870	55880	50		122075R4
010-03896	55881	100		122150R4
010-03839	55878	150		122250R4
010-03813	55877	200		122300R4

— End of Specification —



Appendix



Appendix 1: Table of Compliance

Line	Criteria	Description	Pass/Fail (P / F)	Comments
1	Specification	The Proponent complies with the corresponding specification document (4350.144).		
2	Industry Standards	The Proponent complies with the industry standards established in the specification document.		
3	Fuse Type	SM-4		
4	Fuse Components	<ul style="list-style-type: none">• Fusible Element• Arcing rod• Solid-material arc-extinguishing medium• Filament-wound glass-epoxy tube		
5	Product Requirement	<ul style="list-style-type: none">• Operating Voltage: 14.4 kV• Maximum Interrupting Current (symmetrical): 12,500 A• Refill suitable for S&C SM-4 fuse holder.		
6	Amp Rating	See table 1 on section 12		

NOTE: This table is only a checklist for reference. The compliance shall be with the complete document. Marking a PASS in the table won't be accepted as a compliance without the technical information required to certify it.











4350.144 SM-4 fuses (09-11-2024)

Final Audit Report

2024-09-11

Created:	2024-09-11
By:	Rodolfo Flores (rodolfo.floresortiz@lumapr.com)
Status:	Signed
Transaction ID:	CBJCHBCAABAA8U40bJSDCTyFzLQbTYF8nCv6YMe38a0

"4350.144 SM-4 fuses (09-11-2024)" History

-  Document created by Rodolfo Flores (rodolfo.floresortiz@lumapr.com)
2024-09-11 - 2:43:44 PM GMT
-  Document emailed to Rodolfo Flores (rodolfo.floresortiz@lumapr.com) for signature
2024-09-11 - 2:43:49 PM GMT
-  Document e-signed by Rodolfo Flores (rodolfo.floresortiz@lumapr.com)
E-signature obtained using URL retrieved through the Adobe Acrobat Sign API
Signature Date: 2024-09-11 - 2:44:23 PM GMT - Time Source: server
-  Document emailed to Miguel Rios (miguel.rioslopez@lumapr.com) for signature
2024-09-11 - 2:44:24 PM GMT
-  Email viewed by Miguel Rios (miguel.rioslopez@lumapr.com)
2024-09-11 - 3:05:05 PM GMT
-  Document e-signed by Miguel Rios (miguel.rioslopez@lumapr.com)
Signature Date: 2024-09-11 - 3:06:42 PM GMT - Time Source: server
-  Document emailed to Ricardo Castro (ricardo.castro@lumapr.com) for signature
2024-09-11 - 3:06:43 PM GMT
-  Email viewed by Ricardo Castro (ricardo.castro@lumapr.com)
2024-09-11 - 8:23:29 PM GMT
-  Document e-signed by Ricardo Castro (ricardo.castro@lumapr.com)
Signature Date: 2024-09-11 - 8:23:40 PM GMT - Time Source: server
-  Agreement completed.
2024-09-11 - 8:23:40 PM GMT