



Document Title:

Electrical Shielding Braid Tape, 1" X 15'

Document Type:

Material Specifications

Document No.:

4350.163

Department:

Distribution Standards & Materials

Issue Date:

September 26, 2022

Effective Date:

Sep 26, 2022

Author

Miguel J. Rios López, PE
Standards Engineer, Distribution Stand & Materials

Signature and Date

Sep 26, 2022

Reviewer

Rafael Torres Martinez, PE
Supervisor, Distribution Standards & Materials

Signature and Date

Por:

Sep 26, 2022

Approver

Ricardo Castro Gómez, PE
Manager, Distribution Standards & Materials

Signature and Date

Sep 26, 2022

Version History

Date	Revision Comments
Sep. 26, 2022	Changed from PREPA format (rev. 3) to LUMA format.

Warehouse Catalog	Item Version	Date
038-01271	4	09/26/2022



Equipment Specification
Document No.: 4350.163
Item No.: 038-01271
Asset Suite: 55008
Originating Department: Distribution Engineering



Electrical Shielding Braid Tape, 1" X 15'

1. Introduction

This is a general specification that covers the minimum requirements for electrical shielding braid tape to be used in the electrical distribution system in Puerto Rico. Further information will be provided by LUMA Energy at the time of order placement and will provide information on site specific conditions, quantity, and other requirements. This document includes the general electrical and mechanical characteristics of the material.

2. Special Requirements

Samples shall be furnished as requested by LUMA Energy. Vendors that have supplied this material to PREPA/LUMA on previous orders, will not have to furnish samples at bid opening. The material will be received at the LUMA's general warehouse (011) at Palo Seco, Puerto Rico. Shipping will include transportation and unloading at the indicated warehouse.

3. Quantity/Literature

Descriptive and technical literature must be supplied by vendor at time of bidding. This literature may include, but is not limited to details of material, drawings, documented testing, and instructions for use and installation. Failure to submit documents on time will cause bidder disqualification. For products described in this specification as requiring qualification, awards will be made only for such products that, prior to the time for opening of bids, had been tested and/or approved by LUMA. Evidence of PREPA's and/or LUMA Energy's approval of the equipment or material shall be supplied by vendor if requested by LUMA Energy.

4. Markings

- 4.1. Containers shall be marked outside with LUMA Energy's purchase order and item number.
- 4.2. Packaging labels and tags shall be waterproof.
- 4.3. Each roll shall be identified in english language with the name of the manufacturer and trademark at the inside of the core.
- 4.4. Each individual container shall be identified as above and shall indicate the nominal width and length of the tape.



Equipment Specification
Document No.: 4350.163
Item No.: 038-01271
Asset Suite: 55008
Originating Department: Distribution Engineering

Electrical Shielding Braid Tape, 1" X 15'

5. Equal or Approved Equal to

- 5.1. 3M: Scotch 24 Electrical Shielding Tape

6. Packaging

All material and equipment shall be packaged and marked in such a way as to facilitate handling and protection from damage and that the receiving warehouse can readily identify it and send it, in one complete unit, to a field location without opening crates or boxes to sort items and/or parts.

7. Number Per Package (Logistics)

Standard package: Ten (10) units per box or as requested by LUMA.

8. Acceptance Criteria

- 8.1. Test required: certified by external laboratories.
- 8.2. Latest applicable codes, standards, and other regulations: ASTM

9. Description

- 9.1. The electrical shielding braid tape is used to provide shielding for power cables in outdoor and indoor applications.
- 9.2. Shall be all metal, open wave, shielding braid tape in a flat, cable-like form.
- 9.3. Material: Tinned Copper.
- 9.4. Dimensions: 1" (2.54 cm) wide and 15' (4.54 m) long.
- 9.5. Shall be stable at elevated temperatures.
- 9.6. Shall be resistant to corrosion, oil, fire, chemical, and weather.
- 9.7. Shall elongate easily to conform to uneven surfaces.

10. Inspection

The acceptance of any material or equipment shall in no way relieve the vendor from his responsibility to meet all the requirements of this specification, and it would not prevent subsequent rejection if such materials were found later to be defective.



Equipment Specification

Document No.: 4350.163

Item No.: 038-01271

Asset Suite: 55008

Originating Department: Distribution Engineering

Electrical Shielding Braid Tape, 1" X 15'

11. Proposal Information

11.1. Submitted proposals must include:

- a. Technical information
- b. Table of Compliance completed by the bidder with reference. (See Appendix 1)

— End of Specification —



Equipment Specification

Document No.: 4350.163

Item No.: 038-01271

Asset Suite: 55008

Originating Department: Distribution Engineering

Electrical Shielding Braid Tape, 1" X 15'

Appendix



Equipment Specification
Document No.: 4350.163
Item No.: 038-01271
Asset Suite: 55008
Originating Department: Distribution Engineering

Electrical Shielding Braid Tape, 1" X 15'

Appendix 1: Table of Compliance

Line	Criteria	Description	Pass/Fail (P/F)	Comments
1	Specification	The Proponent complies with the corresponding specification document 4350.163.		
2	Industry Standards	The Proponent complies with the industry standards established in the specification document. (ASTM)		
3	Type	Braid		
4	Material	<ul style="list-style-type: none">• Tinned Copper		
5	Product Requirement	<ul style="list-style-type: none">• Resistant to corrosion, oil, fire, chemical, and weather.• Shall elongate easily to conform to uneven surfaces.		











4350.163 Electrical Shielding Braid Tape, 1in X 15ft (9-26-22)

Final Audit Report

2022-09-26

Created:	2022-09-26
By:	Miguel Rios (miguel.rioslopez@lumapr.com)
Status:	Signed
Transaction ID:	CBJCHBCAABAAlb0oVppghBoywisBhZE5zLGaPrfNNdkU

"4350.163 Electrical Shielding Braid Tape, 1in X 15ft (9-26-22)" History

-  Document created by Miguel Rios (miguel.rioslopez@lumapr.com)
2022-09-26 - 3:58:00 PM GMT
-  Document e-signed by Miguel Rios (miguel.rioslopez@lumapr.com)
Signature Date: 2022-09-26 - 4:02:24 PM GMT - Time Source: server
-  Document emailed to ricardo.castro@lumapr.com for signature
2022-09-26 - 4:02:26 PM GMT
-  Email viewed by ricardo.castro@lumapr.com
2022-09-26 - 6:16:27 PM GMT
-  Signer ricardo.castro@lumapr.com entered name at signing as Ricardo Castro Gómez
2022-09-26 - 6:17:30 PM GMT
-  Document e-signed by Ricardo Castro Gómez (ricardo.castro@lumapr.com)
Signature Date: 2022-09-26 - 6:17:32 PM GMT - Time Source: server
-  Document emailed to ricardo.castro@lumapr.com for signature
2022-09-26 - 6:17:34 PM GMT
-  Email viewed by ricardo.castro@lumapr.com
2022-09-26 - 7:18:28 PM GMT
-  Signer ricardo.castro@lumapr.com entered name at signing as Ricardo Castro Gómez
2022-09-26 - 7:20:56 PM GMT
-  Document e-signed by Ricardo Castro Gómez (ricardo.castro@lumapr.com)
Signature Date: 2022-09-26 - 7:20:58 PM GMT - Time Source: server

✔ Agreement completed.

2022-09-26 - 7:20:58 PM GMT