



Document Title:
Cutout Bypass Tool

Document Type:
Material Specifications

Document No.:
4350.299

Originating Department:
Distribution Standards & Materials

Effective Date:
Feb 16, 2023

Author Rodolfo A Flores Ortiz, PE Standards Engineer, Distribution Standards & Materials	Signature and Date  Feb 16, 2023
Reviewer Rafael Torres Martinez, PE Supervisor, Distribution Standards & Materials	Signature and Date  Feb 16, 2023
Approver Ricardo Castro Gómez, PE Manager, Distribution Standards & Materials	Signature and Date  Feb 16, 2023

Document History

Date	Revision Comments
Feb. 16, 2022	Initial Release.

Warehouse Catalog	Item Version	Date
072-84016	1	02/16/2023



Equipment Specification
Document No.: 4350.299
Item No.: 072-84016
Asset Suite: 84016
Originating Department: Distribution Engineering



Cutout Bypass Tool

1. Introduction

This is a general specification that covers the minimum requirements for the cutout bypass tool used in the distribution system in Puerto Rico. Further information will be provided by LUMA Energy at the time of order placement and will provide information on site specific conditions, quantity, and other requirements. This document includes the general electrical and mechanical characteristics of the material.

2. Special Requirements

Samples shall be furnished as requested by LUMA Energy. Vendors that have supplied this material to PREPA / LUMA on previous orders, will not have to furnish samples at bid opening. The material will be received at the LUMA's general warehouse (011) at Palo Seco, Puerto Rico. Shipping will include transportation and unloading at the indicated warehouse.

3. Quantity/Literature

Descriptive and technical literature must be supplied by vendor at time of bidding. This literature may include, but is not limited to details of material, drawings, documented testing, and instructions for use and installation. Failure to submit documents on time will cause bidder disqualification. For products described in this specification as requiring qualification, awards will be made only for such products that, prior to the time for opening of bids, had been tested and/or approved by LUMA. Evidence of PREPA's and/or LUMA Energy's approval of the equipment or material shall be supplied by vendor if requested by LUMA Energy.

4. Markings

- 4.1. Containers shall be marked outside with LUMA Energy's purchase order and item number.
- 4.2. Packaging labels and tags shall be waterproof.

5. Equal or Approved Equal to

Utility Solutions, model USJJ-002-S



Equipment Specification

Document No.: 4350.299

Item No.: 072-84016

Asset Suite: 84016

Originating Department: Distribution Engineering

Cutout Bypass Tool

6. Packaging

All material and equipment shall be packaged and marked in such a way as to facilitate handling and protection from damage and that the receiving warehouse can readily identify it and send it, in one complete unit, to a field location without opening crates or boxes to sort items and/or parts.

7. Number Per Package (Logistics)

Standard package: One (1) unit per package or as requested by LUMA Energy.

8. Acceptance Criteria

- 8.1. Test required: certified by external laboratories.
- 8.2. Latest applicable codes, standards, and other regulations

9. Description

- 9.1. Cutout bypass tool used for temporarily circumvent overhead cutouts.
- 9.2. This tool shall be composed of two metallic head connected with a stainless-steel spring.
- 9.3. Each head shall be manufactured with multiple loops and a hook that permits for handling and installing on the cutout's live parts.
- 9.4. Electrical characteristics:
 - a. Voltage: 27 kV
 - b. Rated current (continuous): 100 A.
- 9.5. The tool shall have a label indicating the rated voltage class.
- 9.6. Shall be able to be installed and removed using a standard shotgun stick.
- 9.7. Approximate dimensions:
 - a. Length: 8.5 in
 - b. Width: 3.5 in
 - c. Maximum stretch: 14 in, minimum
- 9.8. Shall be provided with an appropriate soft case for storage.



Equipment Specification

Document No.: 4350.299

Item No.: 072-84016

Asset Suite: 84016

Originating Department: Distribution Engineering

Cutout Bypass Tool

10. Inspection

The acceptance of any material or equipment shall in no way relieve the vendor from his responsibility to meet all the requirements of this specification, and it would not prevent subsequent rejection if such materials were found later to be defective.

11. Proposal Information

11.1. Submitted proposals must include:

- a. Technical information
- b. Table of Compliance completed by the bidder with reference. (See Appendix 1)

— End of Specification —



Equipment Specification

Document No.: 4350.299

Item No.: 072-84016

Asset Suite: 84016

Originating Department: Distribution Engineering

Cutout Bypass Tool

Appendix



Equipment Specification
Document No.: 4350.299
Item No.: 072-84016
Asset Suite: 84016
Originating Department: Distribution Engineering

Cutout Bypass Tool

Appendix 1: Table of Compliance

Line	Criteria	Description	Pass/Fail (P/F)
1	Specification	The Proponent complies with the corresponding specification document.	
2	Industry Standards	The Proponent complies with the industry standards established in the specification document. (ANSI, ASTM)	
3	Construction	<ul style="list-style-type: none">• This tool shall be composed of two metallic head connected with a stainless-steel spring.• Each head shall be manufactured with multiple loops and a hook that permits for handling and installing on the cutout's live parts.	
4	Electrical characteristics	<ul style="list-style-type: none">• Voltage: 27 kV• Rated current (continuous): 100 A.	
5	Installation	Shall be able to be installed and removed using a standard shotgun stick.	
6	Dimensions	<ul style="list-style-type: none">• Length: 8.5 in• Width: 3.5 in• Maximum stretch: 14 in, minimum	
7	Accessories	Soft case	











4350.299 Cutout Bypass Tool (02-16-2023)

Final Audit Report

2023-02-16

Created:	2023-02-16
By:	Rodolfo Flores (rodolfo.floresortiz@lumapr.com)
Status:	Signed
Transaction ID:	CBJCHBCAABAA2T-9zByctb4nyv0WqMRNyHj2RKKZ7xOv

"4350.299 Cutout Bypass Tool (02-16-2023)" History

-  Document created by Rodolfo Flores (rodolfo.floresortiz@lumapr.com)
2023-02-16 - 1:50:20 PM GMT
-  Document e-signed by Rodolfo Flores (rodolfo.floresortiz@lumapr.com)
Signature Date: 2023-02-16 - 1:55:21 PM GMT - Time Source: server
-  Document emailed to Rafael Torres-Martinez (rafael.torresm@lumapr.com) for signature
2023-02-16 - 1:55:22 PM GMT
-  Email viewed by Rafael Torres-Martinez (rafael.torresm@lumapr.com)
2023-02-16 - 2:09:56 PM GMT
-  Document e-signed by Rafael Torres-Martinez (rafael.torresm@lumapr.com)
Signature Date: 2023-02-16 - 2:10:40 PM GMT - Time Source: server
-  Document emailed to ricardo.castro@lumapr.com for signature
2023-02-16 - 2:10:42 PM GMT
-  Email viewed by ricardo.castro@lumapr.com
2023-02-16 - 3:41:11 PM GMT
-  Signer ricardo.castro@lumapr.com entered name at signing as Ricardo Castro Gómez
2023-02-16 - 5:04:10 PM GMT
-  Document e-signed by Ricardo Castro Gómez (ricardo.castro@lumapr.com)
Signature Date: 2023-02-16 - 5:04:12 PM GMT - Time Source: server
-  Agreement completed.
2023-02-16 - 5:04:12 PM GMT