



	Document Title: Armor Rod 3#6 OHGW		
	Document Type: Equipment Specification	Document No.: 4752.271	
Department: Transmission Engineering	Version: 01	Issue Date: 5/19/2022	Effective Date: 5/19/2022

<p>Author Emmanuel E Rivera Cruz Designer, Transmission & Substation Engineering</p> <p>Reviewer 1 Rene Maldonado Supervisor, Line Engineering Standards</p> <p>Reviewer 2 Oscar Venegas Lead Engineer, Trans</p> <p>Approver Walter Carrasquillo Alberty Manager, T&S Standards and Materials</p>	Signature and Date Emmanuel E Rivera Cruz (Jun 2, 2022 16:48 EDT)
	Signature and Date Rene Maldonado (Jun 3, 2022 08:26 EDT)
	Signature and Date Oscar E Venegas (Aug 10, 2022 11:39 EDT)
	Signature and Date Walter Carrasquillo (Aug 10, 2022 13:53 EDT)

Management Approval	
Heriberto González Section Manager, Standards	Signature and Date
Darrel Wilvers Director, Asset Management	Signature and Date N/A

Version History					
Version	Date	Revision Comments	Author	Reviewers	Approver
00	Dec 28, 2021		Rene Maldonado	Heriberto Gonzalez	Walter Carrasquillo
01	May 19, 2022	General revision for final approval	Emmanuel E. Rivera	Rene Maldonado Oscar Venegas	Walter Carrasquillo



1. General

- 1.1. This is a general specification that covers the minimum requirements for Armor Rod 3#6 OHGW to be used in the transmission system in Puerto Rico.
- 1.2. Further information will be provided by LUMA Energy at the time of order placement and will provide information on site conditions, quantity, and other requirements.
- 1.3. This document includes the general electrical and mechanical characteristics of the material.

2. Specific Name

- 2.1. Armor Rod 3#6 OHGW.

3. Basic Use

- 3.1. For provide mechanical support and repair the 3#6 overhead ground wire guy wire used on the transmission line system.

4. Special Requirements

- 4.1. Samples shall be furnished if requested by LUMA.
- 4.2. LUMA may require one (1) unit properly labeled for testing and analysis.
- 4.3. Descriptive and technical literature shall be supplied if requested by LUMA.

5. Marking and Packaging

- 5.1. All material and equipment shall be packaged and marked in such a way as to facilitate handling and protection from damage and that the receiving warehouse can readily identify it and send it, in one complete unit, to a field location without opening crates or boxes to sort items and/or parts.

6. Equal or approved equal to:

- 6.1. Preformed Line Products Catalog No. AR-2326 (Color Code: Yellow)

7. Number per package:

- 7.1. Pallet quantity: as requested by LUMA.

8. Acceptance Criteria

- 8.1. Latest applicable codes, standards, and other regulations: ANSI/ASTM.

9. Description

9.1. The armor rods are designed to protect cable against bending, compression, abrasion, arc-over, and to provide repair. They are also used to repair damaged aluminum-based conductors and restore the conductors' mechanical strength and conductivity.

9.2. Specifications:

9.2.1. Single Support Length (S): 50".

9.2.2. Diameter Range: 0.334" – 0.352".

9.2.3. Weight Per Carton: 35 lbs.

9.2.4. Rod Diameter: 0.114".


9.2.5. Rods per Set: 10.

9.3. Metric conversion as per latest ASTM.

10. Inspection

10.1. The acceptance of any material or equipment shall in no way relieve the vendor from his responsibility to meet all the requirements of this specification, and it shall not prevent subsequent rejection if such material is found to be defective later.

11. Drawing



— End of Specification —












4752.271 Armor Rod 3#6 OHGW


Final Audit Report

2022-08-18


Created:	2022-06-02
By:	Emmanuel E Rivera Cruz (emmanuel.riveracruz@lumapr.com)
Status:	Signed
Transaction ID:	CBJCHBCAABAAMQg64otM1P1igwSiHWwGUp9INDufJYY_

"4752.271 Armor Rod 3#6 OHGW" History


-  Document created by Emmanuel E Rivera Cruz (emmanuel.riveracruz@lumapr.com)
2022-06-02 - 8:43:24 PM GMT
-  Document e-signed by Emmanuel E Rivera Cruz (emmanuel.riveracruz@lumapr.com)
Signature Date: 2022-06-02 - 8:48:23 PM GMT - Time Source: server
-  Document emailed to Rene Maldonado (rene.maldonado@lumapr.com) for signature
2022-06-02 - 8:48:25 PM GMT
-  Email viewed by Rene Maldonado (rene.maldonado@lumapr.com)
2022-06-02 - 8:48:29 PM GMT
-  Document e-signed by Rene Maldonado (rene.maldonado@lumapr.com)
Signature Date: 2022-06-03 - 12:26:25 PM GMT - Time Source: server
-  Document emailed to oscar.venegas@lumapr.com for signature
2022-06-03 - 12:26:27 PM GMT
-  Email viewed by oscar.venegas@lumapr.com
2022-06-03 - 12:26:31 PM GMT
-  Email viewed by oscar.venegas@lumapr.com
2022-06-12 - 12:31:33 PM GMT
-  Email viewed by oscar.venegas@lumapr.com
2022-08-10 - 3:21:14 PM GMT
-  Signer oscar.venegas@lumapr.com entered name at signing as Oscar E Venegas
2022-08-10 - 3:39:39 PM GMT
-  Document e-signed by Oscar E Venegas (oscar.venegas@lumapr.com)
Signature Date: 2022-08-10 - 3:39:40 PM GMT - Time Source: server- Signature captured from device with phone number XXXXXXXX2079

 Document emailed to Walter Carrasquillo (walter.carrasquillo@lumapr.com) for signature


2022-08-10 - 3:39:42 PM GMT

 Email viewed by Walter Carrasquillo (walter.carrasquillo@lumapr.com)

2022-08-10 - 5:52:17 PM GMT

 Document e-signed by Walter Carrasquillo (walter.carrasquillo@lumapr.com)

Signature Date: 2022-08-10 - 5:53:07 PM GMT - Time Source: server

 Document emailed to Heriberto Gonzalez (heriberto.gonzalez@lumapr.com) for signature

2022-08-10 - 5:53:08 PM GMT

 Document e-signed by Heriberto Gonzalez (heriberto.gonzalez@lumapr.com)

E-signature obtained using URL retrieved through the Adobe Acrobat Sign API

Signature Date: 2022-08-18 - 1:29:10 PM GMT - Time Source: server

 Agreement completed.

2022-08-18 - 1:29:10 PM GMT