



Document Title:  
**Fiberglass Crossarm-Dead End (5 ft. and 8 ft.) and Alley Arm (8 ft.)**

Document Type:  
**Specification**

Engineering Type  
**Material Specification**

Document No.:  
**4300.50.351**

Department:  
**Distribution Engineering**

Version:  
**03**

Effective Date:  
**Aug 7, 2025**

For others, specify here

**Shared document with: N/A**

*\*Select the Departments impacted by the document (If apply)*

For others, specify here

**Author**

Rosalía Alverio González  
Technical Specialist III, Distribution Standards & Materials

Signature and Date:

Aug 7, 2025

**Reviewer**

Rodolfo A. Flores Ortiz, PE (Lic. 27131)  
Senior Engineer, Distribution Standards & Materials

Signature and Date:

Aug 7, 2025

**Approver**

Ricardo Castro Gómez, PE (Lic. 12135)  
Manager, Distribution Standards & Materials

Signature and Date:

Aug 7, 2025

**Management Approval (If apply)**

**Approver**

Name  
Position

Signature and Date:

**Related/Referenced Documents**

N/A

**Version History**

Version	Date	Revision
01	June 17, 2025	Initial Release. Items 008-82814, 008-82815, and 008-83421 were transferred from document 4350.155 and 4350.189 respectively. This document supersedes documents 4350.155 and 4350.189.
02	July 23, 2025	Modified Section 8: 8.2 (d) and 8.3 (e).
03	August 7, 2025	Modified Section 9 and changed Document number (Legacy Number: 4350.351) to new Engineering Records nomenclature number 4300.50.351.



### Item Version History

Warehouse Catalog #	Asset Suite #	Version	Date
008-82814	82814	8	8/7/2025
008-82815	82815	8	8/7/2025
008-83421	83421	5	8/7/2025



## **1. Introduction**

This is a general specification that covers the minimum requirements for the fiberglass crossarm dead end and the fiberglass crossarm alley arm to be used in the Distribution System in Puerto Rico. Further information will be provided by LUMA Energy at the time of order placement and will provide information on site specific conditions, quantity, and other requirements. This document includes the general characteristics of the equipment/material.

## **2. Special Requirements**

Samples shall be furnished as requested by LUMA Energy. Vendors that have supplied this equipment/material to LUMA on previous orders, will not have to furnish samples at bid opening. The equipment/material will be received at LUMA's general warehouse (011) at Palo Seco, Puerto Rico. Shipping will include transportation and unloading at the indicated warehouse.

## **3. Literature**

- 3.1. Descriptive and technical literature must be supplied by the vendor at time of bidding. This literature must include, but is not limited to, details of material, drawings, documented testing, and instructions for use and installation. The literature must be an official document from and certified by the manufacturer.  
**Failure to submit documents on time and duly certified by the manufacturer will cause bidder disqualification.**
- 3.2. If required by LUMA, final drawings and documentation shall be submitted by the vendor before the manufacturing and shipping process for approval.

#### **4. Compatible with**

For compatible manufacturer and model see Table 1. These models are examples of the equipment/material described in this document and do not represent a preference. LUMA will evaluate equally any model not listed here during any acquisition event.

#### **5. Markings**

- 5.1. Containers shall be marked outside with LUMA Energy's purchase order and item number.
- 5.2. Individual package(s) shall be clearly marked with manufacturer name and item information (part number, serial number, quantity, etc.).
- 5.3. Packaging labels and tags shall be waterproof.

#### **6. Packaging**

- 6.1. All equipment/material shall be packaged and marked in such a way as to facilitate handling and protection from damage and that the receiving warehouse can readily identify it and send it, in one complete unit, to a field location without opening crates or boxes to sort items and/or parts.
- 6.2. A list of all parts included in the container and/or package must be provided at the time of delivery so the receiving personnel can verify that everything requested is present, avoiding any delay in the receiving process.

#### **7. Number Per Package (Logistics)**

Each manufacturer should define the number of crossarm per package depending on the shipping on open platforms or closed trailers for delivery according to LUMA requirements or as requested by LUMA.

#### **8. Acceptance Criteria**

- 8.1. Test required: certified by external qualified laboratories.
- 8.2. Product shall be manufactured in accordance with the latest issue below (section 7.3). When conflicts occur between purchaser's specifications and the latest issue below, the purchaser's specification shall prevail.
- 8.3. Latest applicable codes, standards, and other regulations:

**ASTM A153**                      Specification for Zinc Coating (Hot Dip) on Iron and Steel Hardware

<b>ASTM A871</b>	Standard Specification for High-Strength Low-Alloy Structural Steel Plate with Atmospheric Corrosion Resistance
<b>ASTM D635</b>	Standard Test Method for Rate of Burning and/or Extent and Time of Burning of Plastics in a Horizontal Position
<b>ASTM 8019</b>	Standard Test Methods for Determining the Full Section Flexural Modulus and Bending Strength of Fiber Reinforced Polymer Crossarms Assembled with Center Mount Brackets.
<b>ASTM G154</b>	Standard Practice for Operating Fluorescent Ultraviolet (UV) Light Apparatus for Exposure of Nonmetallic Materials
<b>ASTM B85/B85M</b>	Standard Specification for aluminum-alloy die castings.
<b>ASTM D570</b>	Standard Specification for Hot-Rolled Carbon Steel Sheet and Strip, Structural Quality
<b>ASTM D2584</b>	Standard Test Method for Ignition Loss of Cured Reinforced Resins
<b>ASTM D3917</b>	Standard Specification for Dimensional Tolerance of Thermosetting Glass-Reinforced Plastic Pultruded Shapes
<b>ASTM D4385</b>	Standard Practice for Classifying Visual Defects in Thermosetting Reinforced Plastic Pultruded Products
<b>ASTM D578</b>	Standard Specification for Glass Fiber Strands
<b>ASTM D570</b>	Standard Specification for Hot-Rolled Carbon Steel Sheet and Strip, Structural Quality
<b>ANSI O5.3</b>	Solid Sawn-Wood Crossarms and Braces - Specifications and Dimensions
<b>ANSI B18.22.1</b>	Type A Standard for washer dimensional requirements.
<b>ASME B1.1</b>	Unified Inch Screw Threads

<b>UL 94</b>	Classification and Flame-Retardant Plastic Materials
<b>AWS D1.1</b>	Structural Welding Code–Steel
<b>RUS 1724e-151</b>	Mechanical Loading on Distribution Crossarms
<b>RUS 1724e-200</b>	Design Manual for High Voltage Transmission Lines
<b>ASCE-SEI-104</b>	American Society of Civil Engineering
<b>IEEE</b>	Standard 4, and IEC 60060-1: Standard for High-Voltage Testing Techniques.

- 8.4. If any other standard different from the ones indicated in this document is used, the supplier must provide information showing compatibility with the required ones.

## 9. Description

- 9.1. The specifications are divided into two parts in the Technical Specifications and the Special Conditions. The Technical Specifications will include the material, design, types of poles to be used crossarm, types of crossarm, forces to be considerate, deflection, drawings, final approval before manufacture, labels and markings. The Special Conditions will include the crossarm color, mounting bracket, hardware, structural steel and accessories, protective coating, material to be considerate, failure to meet the specification and guarantee.

### 9.2. Technical Specifications

a. Material:

The crossarm materials shall be composed of boron-free continuous glass fiber reinforcement by ASTM D578 and thermoset resin system. The crossarm material shall be self-extinguishing.

b. Design:

1. The supplier is responsible for the design.
2. The bidder shall submit all the design parameters, either with the runs of the program he used for his analysis or other software to prove it. **Should they do not prove their design parameters, they will be automatically disqualified.**

c. Types of poles to be used crossarm:


The crossarm base will be used for galvanized steel dodecagonal, square prestressed concrete, and fiber reinforce composites poles with heights from 35 ft. to 65 ft.

d. Types of crossarms:


The crossarm provides crucial support to balance the tension of conductors at corners, along angled sections, and in areas with switch installations:

**1. 5 ft. Crossarm: (Dead End):**

- a. The crossarm shall feature four 13/16 in. diameter holes with a bolt sleeve positioned inside each hole.
- b. Looking at the crossarm from above, the distance from each end to the nearest hole shall be 6 in. (see top view in figure below).
- c. When viewed from the front, the distance from the end of the crossarm to the nearest hole shall be 4 in. (see front view in figure below).
- d. The crossarm's cross-section should be at least 4-5/8 in. by 3-5/8 in., or as otherwise determined by design requirements.
- e. A bracket shall be located at the center of the crossarm. The base that is shown in the drawing is for illustrative purposes only. The designer will have the task of making the mounting according to the specifications requested here. (See 8.2 e).




TOP VIEW



FRONT VIEW

## 2. 8 ft. Crossarm: (Dead End):


- a. The crossarm shall feature eight 13/16 in. diameter holes, with a bolt sleeve positioned inside each hole.
- b. Viewed from above, the crossarm has its first hole located 4 in. from each end. The second hole is located 2 ft.-9 in. from the end of the crossarm and is located 2 ft.-5 in. from the first hole.
- c. Viewed from the front, the first hole is 6 in. from each end of the crossarm. The second hole is 2 ft.-7 in. from the end of the crossarm and is located 2 ft.-1 in. from the first hole.
- d. The crossarm's cross-section should be at least 4-5/8 in. by 3-5/8 in., or as otherwise determined by design requirements.
- e. A bracket shall be located at the center of the crossarm. The base that is shown in the drawing is for illustrative purposes only. The designer will have the task of making the mounting according to the specifications requested here. (See 8.2 e).




### **3. 8 ft. Alley Arm crossarm:**

- a. The alley arm crossarm is used to support overhead conductors when a displacement in the alignment of electrical power lines is required.
- b. The alley arm crossarm consists of one horizontal fiberglass beam with the support bracket located near one end and one diagonal fiberglass beam for reinforcement.
- c. The horizontal beam comprises five 13/16 in. diameter holes and a bolt sleeve positioned inside each hole.
- d. The support beam must have a 13/16 in. hole at the pole end that allows for mounting. This hole must align with the crossarm bracket above.
- e. The alley arm's cross-section for the horizontal and support beam should be at least 4-5/8 in. by 3-5/8 in., or as otherwise determined by design requirements.
- f. Two possible cases for the construction of the crossarm are described below:
  1. **Case 1:** When viewed from the top (see figure below), the distance from the center of the mounting bracket to a first hole shall be 31 in. A second hole must be located 25 in. away from the first hole. A third hole shall be positioned 25 in. away from the second hole and 4 in. away from the end of the crossarm (unattached end). Therefore, the third hole will be located 81 inches from the center of the mounting bracket.

When viewed from the front, the distance from the end of the crossarm (attached end) to a first hole shall be 45 in., and a second hole must be located 44 in. away from the first hole (see figure below).



2. **Case 2:** As seen in the figure below, a hole shall be located 81 in. (6 ft.-9 in.) away from the center of the mounting bracket and 4 in. away from the end of the crossarm (unattached end).




e. Forces to be considered:

1. Loading on crossarm is the sum of the following forces when applicable: conductor tensions, weight of conductors, and the force of the wind on conductors and the crossarm.
2. Unbalanced loading can occur when the tensions in the conductors that are attached “into” and “out from” the crossarm assembly are unequal because of:
  - a. Change in conductor size or type.
  - b. Different installation tensions.
  - c. Unequal wind loading.
  - d. Different ruling spans.
3. Longitudinal, Vertical and Transversal Loads:

Description	No. of Wires	Strength Rating Minimum Ultimate Longitudinal Load per wire (lbs.)	Ultimate Longitudinal Capacity (lb)	Ultimate Vertical Capacity (lb)	Ultimate Transversal Capacity (lb)
5 ft - DE	2	3,500	7,000	1,800	500
8 ft - DE	4	3,250	13,000	3,100	500

Description	No. of Wires	Strength Rating Minimum Ultimate Vertical Load per wire (lbs.)	Ultimate Longitudinal Capacity (lb)	Ultimate Vertical Capacity (lb)	Ultimate Transversal Capacity (lb)
8 ft – AA- C1/C2	4	1,750	500	7,000	500

**a. Pattern of loads assumed:**



**f. Deflection:**

Deflection is the displacement of the crossarm under load and is published in inches of displacement per 1000 lbs. of load applied.

**g. Drawings:**

The bid proposal drawings shall include original documents with the following information:

1. General dimensions of all the structural components.
2. Weight for each crossarm (all accessories installed).
3. A bill of materials.
4. Details of all accessories including bolts, nuts, and washers to attach mounting bracket to the fiberglass beam, etc.

**h. Final approval before manufacturing:**

1. Final design calculations shall be submitted before fabrication commences together with the shop drawing for LUMA approval.
2. After approval, one final set of drawings and design calculations in PDF format plus, a digital copy of drawings in AutoCAD 3D (DWG) shall be sent for our files.

3. All drawings shall include our purchase order number.

i. Labels and markings:

1. Each crossarm shall have waterproof and legible identification labels.
2. The labels shall be 4 in. x 2 ½ in. approx. in dimension, stamped with letters.
3. The labels shall contain the following minimum information:
  - a. Owner's name
  - b. Warehouse Number
  - c. Country
  - d. Fabrication Date: MM/YY
  - e. Batch Number
  - f. RFQ Number or PO Number
  - g. Model
  - h. Dimension (L x W x H)
  - i. Weight
  - j. Manufacturer's Name

**9.3. Special Conditions**

a. Crossarm color:

The crossarm color shall be gray.

b. Mounting bracket:

1. The center mount bracket must be heavy duty type made of cast aluminum drilled and tapped.
2. Mounting holes must be 13/16 in. in diameter with 8 in. and 12 in. center to center spacing or, alternatively, with 12 in. and 16 in. center to center spacing.

c. Hardware, structural steel and accessories:

1. Mounting bracket shall be made of 6061-T6 aluminum, hot-rolled steel, or welded structural steel.
2. All hardware, including mounting bracket, bolts, washers, and nuts shall be hot-dipped galvanized in accordance with ASTM A153. In addition, an open hole plug must be installed (included in this order).
- d. Protective coating:
  1. The crossarm shall be treated with UV-resistant coating to protect against UV degradation.
  2. The crossarm shall be tested for accelerated weathering and ultraviolet aging for 10,000 hours without any degradation of strength or modulus of elasticity (MOE), without deterioration of color, and shall show no visual evidence of exposed glass fibers or other reinforcements when tested in accordance with ASTM G154.
  3. UV coating shall have a minimum protective life expectancy of 40 years.
- e. Material to be considered:
  1. Conductors, insulator, and clamp:
    - a. **556.5 MCM Parakeet**
      1. Minimum Ultimate Strength: 19,800 lbf.
      2. Strands & Diameters: 24/7
      3. Overall Diameter: 0.914 in.
      4. Weight/1000 ft: 716.8 pounds
    - b. **266.8 MCM Partridge**
      1. Minimum Ultimate Strength: 11,240 lbf.
      2. Strands & Diameters: 26/7
      3. Overall Diameter: 0.642 in.
      4. Weight/1000 ft: 367.3 lbs.
    - c. **3/0 AWG Pigeon**
      1. Minimum Ultimate Strength: 6,620 lbf
      2. Strands & Diameters: 6/1

3. Overall diameter: 0.502 in.
4. Weight/1000 ft: 230.8 lbs.
- d. **Suspension Insulator 25 kV**
  1. Mechanical Load (SML): 15,000 lbf.
- e. **Suspension Clamp**
  1. Minimum Ultimate Strength: 25,000 lbf
  2. Approx. Length: 9.9 in.
  3. Approx. Weight: 4.9 lbs.
- f. **Alumoweld Messenger Wire**
  1. Messenger wire 7#7
    - a. Breaking Strength: 19,060 lbf.
    - b. Strand & Diameter: 0.1327 in.
    - c. Approx. Overall Diameter: 0.433 in.
    - d. Weight: 330 lbs./kft.
  2. Messenger wire 19#8:
    - a. Breaking Strength: 19,060 lbf.
    - b. Strand & Diameter: 0.1327 in.
    - c. Approx. Overall Diameter: 0.433 in.
    - d. Weight: 330 lbs./kft.
- g. 15 kV Spacer for 3 Conductors and Messenger: A mechanism (e.g., preformed ties) shall be provided to secure the spacer to the messenger and the conductors. The ties shall be of the same material as the spacer and for cables with a diameter of up to 2 in. The messenger can be up to 0.750 in. diameter and the phase conductors can be up to 2 in. diameter., maximum weight shall not exceed 3 pounds, and for steep grade applications (greater than 20 degrees).

f. Failure to meet the specification and guarantee:

1. In the event that any equipment fails to comply with the warranties and requirements of these specifications within the period proposed or indicated, it shall be at the option of the LUMA representative to accept the material or reject it and instruct the manufacturer to proceed immediately to make such modifications or supply such new parts as may be necessary to bring it into compliance with the warranties and requirements.
2. All costs of supplying and installing new parts due to non-compliance of material with warranties and other specification requirements shall be the responsibility of the manufacturer.

## 10. Inspection

- 10.1. Upon inspection of incoming equipment/material, the purchaser reserves the right to refuse product shipments and to determine the acceptability or rejection of the product received. The supplier shall be liable for all costs incurred for a product that is rejected.
- 10.2. The acceptance of any equipment/material shall in no way relieve the vendor from his responsibility to meet all the requirements of this specification, and it would not prevent subsequent rejection if such equipment/materials were found later to be defective.

## 11. Proposal Information

- 11.1. Submitted proposals must include:
  - a. Technical information, drawings, and tests.
  - b. Table of Compliance completed by the bidder with reference (see Appendix 1).

## 12. Table 1: Warehouse and Asset Suite Identification Number

Crossarm Type	Warehouse Catalog #	Asset Suite #
5 ft. Crossarm-DE	008-82814	82814
8 ft. Crossarm-DE	008-82815	82815
8 ft. Alley Arm	008-83421	83421

**DE: DEADEND**

## Appendix

## Appendix 1: Table of Compliance

Line	Description	Pass/Fail (P / F)	Comments
<b>Industry Standards</b>			
1	The Proponent complies with the industry standards established in the specification document (ANSI, ASTM, See Section 7.3)		
	ASTM G154 / ASTM D578		
	UL 94		
<b>Literature</b>			
2	Technical Information		
	Drawings		
	Descriptive and technical literature must be supplied by the vendor at time of bidding. This literature must include, but is not limited to, details of material, drawings, documented testing, and instructions for use and installation. The literature must be an official document from and certified by the manufacturer. <b>Failure to submit documents on time and duly certified by the manufacturer will cause bidder disqualification.</b>		
<b>Material</b>			
3	ASTM D578 and thermoset resin system.		
<b>Design</b>			
4	The bidder shall submit all the design parameters, either with the runs of the program he used for his analysis or other software to prove it. Should they do not prove their design parameters, they will be automatically disqualified.		
<b>Types of Crossarm</b>			
5	<b>5 ft.-DE-</b> The crossarm shall feature four 13/16" diameter holes with a bolt sleeve positioned inside each hole. Looking at the crossarm from above, the distance from each end to the nearest hole shall be 6" (see top view in figure below). When viewed from the front, the distance from the end of the crossarm to the nearest hole shall be 4" (see front view in figure below). The crossarm's cross-section should be at least 4-5/8" by 3-5/8", or as otherwise determined by design requirements. A bracket shall be located at the center of the crossarm. The base that is shown in the drawing is for illustrative purposes only. The designer will have the task of making the mounting according to the specifications requested here. (See 8.3 b).		
	<b>8-Ft.-DE-</b> The crossarm shall feature eight 13/16" diameter holes, with a bolt sleeve positioned inside each hole. Viewed from above, the crossarm has its first hole located 4" from each end. The second hole is located 2'-9" from the end of the crossarm and is located 2'-5" from the first hole. Viewed from the front, the first hole is 6" from each end of the crossarm. The second hole is 2'-7" from the end of the crossarm and is located 2'-1" from the first hole. The crossarm's cross-section should be at least 4-5/8" by 3-5/8", or as otherwise determined by design requirements. A bracket shall be located at the center of the crossarm. The base that is shown in the drawing is for illustrative purposes only. The designer will have the task of making the mounting according to the specifications requested here. (See 8.3 b).		

	<p><b>8-Ft-AA-</b>The alley arm crossarm is used to support overhead conductors when a displacement in the alignment of electrical power lines is required. The alley arm crossarm consists of one horizontal fiberglass beam with the support bracket located near one end and one diagonal fiberglass beam for reinforcement. The horizontal beam comprises five 13/16 in. diameter holes and a bolt sleeve positioned inside each hole. The support beam must have a 13/16 in. hole at the pole end that allows for mounting. This hole must align with the crossarm bracket above. The alley arm's cross-section for the horizontal and support beam should be at least 4-5/8 in. by 3-5/8 in., or as otherwise determined by design requirements.</p>		
<b>Forces</b>			
6	<p><b>5 ft – DE-</b> No. of Wires-2 / Strength Rating Minimum Ultimate Longitudinal Load per wire (lbs.)-3,500 / Ultimate Longitudinal Capacity (lb)-7,000 / Ultimate Vertical Capacity (lb)-1,800 / Ultimate Transversal Capacity (lb)-500. <b>8 ft - DE -</b> No. of Wires-4 / Strength Rating Minimum Ultimate Longitudinal Load per wire (lbs.)-3,250 / Ultimate Longitudinal Capacity (lb)-13,000 / Ultimate Vertical Capacity (lb)-3,100 / Ultimate Transversal Capacity (lb)-500. <b>8 ft – AA-C1/C2 -</b> No. of Wires-4 / Strength Rating Minimum Ultimate Longitudinal Load per wire (lbs.)-1,750 / Ultimate Longitudinal Capacity (lb)-500 / Ultimate Vertical Capacity (lb)-7,000 / Ultimate Transversal Capacity (lb)-500.</p>		
<b>Deflection</b>			
7	Deflection is the displacement of the crossarm under load and is published in inches of displacement per 1000 pounds of load applied.		
<b>Crossarm Color</b>			
8	Gray		
<b>Mounting Bracket</b>			
9	The center must be heavy duty type made of cast aluminum drilled and tapped. Mounting holes at mounting plate must be 13/16 in. in diameter with 8 in. and 12 in. center to center spacing or, alternatively, with 12 in. and 16 in. center to center spacing.		
<b>Hardware, Structural Steel and Accessories</b>			
10	Mounting bracket shall be made of 6061-T6 aluminum, hot-rolled steel, or welded structural steel. All hardware, including mounting bracket, bolts, washers, and nuts shall be hot-dipped galvanized in accordance with ASTM A153 and shall have a finger-free fit.		
<b>Protective Coating</b>			
11	Shall be treated with UV-resistant coating to protect against UV degradation.		
	Shall be tested for accelerated weathering and ultraviolet aging for 10,000 hours without any degradation of strength or modulus of elasticity (MOE), without deterioration of color, and shall show no visual evidence of exposed glass fibers or other reinforcements when tested in accordance with ASTM G154.		
	UV coating shall have a minimum protective life expectancy of 40 years.		

**NOTE: This table is only a checklist for reference. The compliance must be with the complete document. Filling out the table with “PASS” won’t be accepted as a compliance without the technical information required to certify it.**











# 4350.351 Fiberglass Crossarm-Dead End (5 ft. and 8 ft.) and Alley Arm (8 ft.)(8-7-2025)

Final Audit Report

2025-08-07

Created:	2025-08-07
By:	Rosalia Alverio (rosalia.alverio@lumapr.com)
Status:	Signed
Transaction ID:	CBJCHBCAABAA_0qfPLpC5iG8ozYrt_9CB8Be16gDZdS3

## "4350.351 Fiberglass Crossarm-Dead End (5 ft. and 8 ft.) and Alley Arm (8 ft.)(8-7-2025)" History

-  Document created by Rosalia Alverio (rosalia.alverio@lumapr.com)  
2025-08-07 - 3:32:01 PM GMT
-  Document emailed to Rosalia Alverio (rosalia.alverio@lumapr.com) for signature  
2025-08-07 - 3:32:06 PM GMT
-  Email viewed by Rosalia Alverio (rosalia.alverio@lumapr.com)  
2025-08-07 - 3:32:34 PM GMT
-  Document e-signed by Rosalia Alverio (rosalia.alverio@lumapr.com)  
Signature Date: 2025-08-07 - 3:33:03 PM GMT - Time Source: server
-  Document emailed to Rodolfo Flores (rodolfo.floresortiz@lumapr.com) for signature  
2025-08-07 - 3:33:05 PM GMT
-  Email viewed by Rodolfo Flores (rodolfo.floresortiz@lumapr.com)  
2025-08-07 - 3:41:38 PM GMT
-  Document e-signed by Rodolfo Flores (rodolfo.floresortiz@lumapr.com)  
Signature Date: 2025-08-07 - 3:47:24 PM GMT - Time Source: server
-  Document emailed to Ricardo Castro (ricardo.castro@lumapr.com) for signature  
2025-08-07 - 3:47:26 PM GMT
-  Email viewed by Ricardo Castro (ricardo.castro@lumapr.com)  
2025-08-07 - 5:49:26 PM GMT
-  Document e-signed by Ricardo Castro (ricardo.castro@lumapr.com)  
Signature Date: 2025-08-07 - 5:55:21 PM GMT - Time Source: server

✔ Agreement completed.

2025-08-07 - 5:55:21 PM GMT



**Adobe Acrobat Sign**